

**City of Pinole**  
**Pinole/Hercules WPCP Project**

**Technical Memorandum 15**

**Hydraulic Profile**

March 1, 2013

**PRELIMINARY  
FOR REVIEW ONLY**



Prepared under the responsible charge of

Craig Olson  
39819



2365 Iron Point Road, Suite 300  
Folsom, CA 95630

## Contents

|  |           |
|--|-----------|
| <b>Executive Summary</b> .....                                       | <b>1</b>  |
| Purpose .....  | 1         |
| Background.....  | 1         |
| Conclusions .....  | 1         |
| <b>Introduction</b> .....  | <b>2</b>  |
| <b>Design Criteria</b> .....   | <b>2</b>  |
| Design Flows .....   | 2         |
| Process Units in Service.....  | 2         |
| <b>Hydraulic Analysis</b> .....                                      | <b>6</b>  |
| ADWF Scenario .....  | 6         |
| MMF and MDF Scenarios.....   | 8         |
| PWWF Scenario .....  | 8         |
| <b>Recommended Project</b> .....                                     | <b>8</b>  |
| <b>Appendix A. Pinole/Hercules WPCP Hydraulic Element List</b> ..... | <b>10</b> |
| <b>Appendix B. Pinole/Hercules WPCP VH Output</b> .....              | <b>11</b> |

## Figures

|   |   |
|---|---|
| Figure 15-1. ADWF/MMF/MDF Flow Path ..... | 4 |
| Figure 15-2. PWWF - Flow Path .....       | 5 |
| Figure 15-3. Hydraulic Profile.....       | 7 |

## Tables

|  |   |
|--|---|
| Table 15-1. Design Flow Scenarios.....                   | 2 |
| Table 15-2. Number of Units in Service .....             | 3 |
| Table 15-3. Flow Modeled Through Each Unit Process ..... | 3 |
| Table 15-4. Unit Process Design Constraints .....        | 9 |

# TM 15 - HYDRAULIC PROFILE

*Pinole/Hercules WPCP Project*

*March 1, 2012*

Reviewed by: Craig Olson, P.E., Mallika Ramanathan, P.E.

Prepared by: Rob Natoli, P.E.

---

## Executive Summary

### Purpose

The purpose of this technical memorandum (TM) is to prepare a detailed hydraulic profile analysis for the proposed process upgrades at the Pinole/Hercules Water Pollution Control Plant (WPCP). Additionally this TM will outline proposed modifications to address hydraulic issues.

### Background

The WPCP was issued a renewed National Pollution Discharge Elimination System (NPDES) permit in August 2012, which contains new treatment and discharge requirements that become effective in 2017. Upgrades to the Headworks, secondary treatment and disinfection system are needed to meet renewed permit requirements. These upgrades will change the hydraulic capacity of the WPCP. This TM presents the hydraulic analysis of flow conditions developed in TM 1 and treatment scenarios developed in TM 8.

### Conclusions

HDR reviewed four hydraulic scenarios:

- ◆ Average Dry Weather Flow (ADWF)
- ◆ Maximum Month Flow (MMF)
- ◆ Maximum Day Flow (MDF)
- ◆ Peak Wet Weather Flow (PWWF)

The existing primary clarifiers and Secondary Clarifier Distribution Box do not have capacity to handle wet weather flows. To mitigate hydraulic issues, flows greater than 12 million gallons per day (mgd) will bypass the primary clarifiers and discharge to the Primary Effluent Junction Box. A new Secondary Clarifier Distribution Box will be constructed to split flow between five secondary clarifiers. Weirs at both primary and secondary clarifiers will be reinstalled to confirm they are at the required elevation. Following construction of the upgrades the secondary system will be able to treat up to 20-

mgd. The costs for the hydraulic improvements discussed in this TM are included in the design costs for the upgrades treatment process they are most closely related to.

## Introduction

Hydraulic analyses were performed to model proposed upgrades to the WPCP to determine if the proposed plant modifications will significantly alter the hydraulic profile of the plant. The NPDES permit requires that all influent flows receive secondary treatment prior to disinfection and discharge to the San Pablo Bay. Currently, the secondary treatment system does not have the hydraulic capacity to treat flows above approximately 11 mgd.

HDR used Visual Hydraulics, a commercial software program, to analyze the future hydraulic profiles. This model was developed using existing plant information and proposed dimensions and elevations for new plant processes. The following sections contain the design criteria used for the hydraulic analysis, a description of the hydraulic analysis and flow scenarios, hydraulic profile figures and a summary of the hydraulic modeling results.

## Design Criteria

The following sections provide the design criteria that are used in the development of the WPCP hydraulic profile for the WPCP upgrades project.

### Design Flows

The basis of hydraulic design flows were developed in TM 1. Flow scenarios include the ADWF, MMF, MDF, and PWWF. Table 15-1 presents the flow components for each design scenario. A description of each flow component can be found in TM 1.

*Table 15-1. Design Flow Scenarios*

| Flow Component                | ADWF (mgd) | MMF (mgd) | MDF (mgd) | PWWF (mgd) | Comment                                  |
|-------------------------------|------------|-----------|-----------|------------|--|
| Combined Influent Flow        | 4.06       | 6.09      | 11.3      | 20         |  |
| Return Activated Sludge (RAS) | 3.25       | 4.87      | 5.65      | 10.00      | 80% of Influent, 50% during storm events |
| Mixed Liquor Recycle (MLR)    | 8.12       | 12.18     | 22.6      | 0          | 200% of Influent, no recycle during PWWF |
| Disinfected Effluent Flow     | 4.06       | 6.09      | 11.3      | 20         |  |

### Process Units in Service

The number of process units in service varies with the flow scenario. During ADWF at least one process unit from each treatment process was modeled as offline to ensure that a unit can be out of service for maintenance and cleaning. Table 15-2 provides a list of the major unit processes modeled and the number of units in service under each flow scenario.

*Table 15-2. Number of Units in Service*

| Unit Process                         | ADWF | MMF | MDF | PWWF | Comment   |
|--------------------------------------|------|-----|-----|------|---|
| Primary Clarifier Distribution Box   | 1    | 1   | 1   | 1    | When influent exceeds 12-mgd, remaining flow is by-passed around the primary clarifiers |
| Primary Clarifiers                   | 2    | 3   | 3   | 3    | Hydraulic capacity of 12-mgd  |
| Primary Effluent Junction Box        | 1    | 1   | 1   | 1    |   |
| Aeration Basins                      | 1    | 2   | 2   | 2    | Contact stabilization is utilized during storm events                                   |
| Secondary Clarifier Distribution Box | 1    | 1   | 1   | 1    |   |
| Secondary Clarifiers                 | 4    | 5   | 5   | 5    | Per new NPDES Permit all flow must receive secondary treatment                          |
| Chlorine Contact Basins              | 1    | 2   | 2   | 2    |   |

Each flow scenario routes specific volumes of flow through each unit process. During ADWF, MMF, and MDF the biological treatment system will operate in a Modified Ludzack-Ettinger (MLE) configuration, with internal mixed liquor recycle. During storm events (prior to and during PWWF), the biological treatment system will operate in contact stabilization mode. This is necessary to stabilize the treatment process during high flow. Table 15-3 provides a list of flows modeled through each unit process for each of the flow scenarios.


*Table 15-3. Flow Modeled Through Each Unit Process*

| Unit Process                         | ADWF  | MMF   | MDF   | PWWF  | Comment  |
|--------------------------------------|-------|-------|-------|-------|--|
| Primary Clarifier Distribution Box   | 4.06  | 6.09  | 11.3  | 12    | By-pass of Primary Clarifiers occurs when flows surpass 12-mgd     |
| Primary Clarifier No. 2              | 1.35  | 2.03  | 3.77  | 4.00  |  |
| Primary Effluent Junction Box        | 7.31  | 10.96 | 16.95 | 20.00 | RAS returned to AB Zone A During Storm Events                      |
| Aeration Basin 3/4                   | 15.43 | 11.57 | 19.78 | 30.00 | Contact Stabilization Mode   |
| Secondary Clarifier Distribution Box | 7.31  | 10.96 | 16.95 | 30.00 | Distribution box weirs are fully submerged at all flow conditions. |
| Secondary Clarifier No. 2            | 2.41  | 3.62  | 5.59  | 9.90  |  |
| Chlorine Contact Basin No. 1         | 2.03  | 3.05  | 5.65  | 10.00 |  |

The hydraulic profile calculations were completed using the longest hydraulic path to achieve conservative results. The ADWF, MMF, and MDF patterns are outlined in Figure 15-1. The following unit processes were used: Chlorine Contact Basin No. 1, Secondary Clarifier No. 2, Aeration Basin 3/4, and Primary Clarifier No. 2. The PWWF pattern is outlined in Figure 15-2.



- LEGEND:
- INFLUENT FLOW
  - RAS FLOW
  - MIXED LIQUOR RECYCLE




PINOLE/HERCULES WPCP PROJECT  
ADWF/MMF/MDF – FLOW PATH



C:\pwworking\sac\d0436859\Figure 15-1.dwg  
03-01-13 RNT/OL 12:14:42

Figure 15-1

C:\pwworking\acc\d0436859\Figure 15-2.dwg  
03-01-13 RNTA01 12:15:20



PINOLE/HERCULES WPCP PROJECT  
 PWWF - FLOW PATH



Figure 15-2

The starting water surface elevation for each flow scenario is calculated as the headloss over the effluent weir in Chlorine Contact Basin. The 2002 Secondary Clarifier Expansion record drawings indicate that the weir elevation is set at 107.15 ft. The final upstream elevation is set at the Primary Clarifier Distribution Box. Weir elevations in this box are manually set with stop logs. For the purpose of this analysis the weir Primary Clarifier Distribution Box weir elevation was assumed to be 117.00 ft.

## Hydraulic Analysis

Four flow patterns were analyzed for this TM, ADWF scenario, MMF scenario, MDF scenario, and the PWWF scenario. All reference elevations for the models are based on the 1929 Datum per the 1971 WPCF drawings. (Yoder – Trotter – Orlob & Associates). A hydraulic profile of the proposed plant upgrades is provided in Figure 15-3. A detailed hydraulic element list for each flow scenario is provided in Appendix A. Descriptions of each flow pattern are presented in the following paragraphs.



### ADWF Scenario

Figure 15-1 illustrates the flow path for this flow scenario. Raw sewage from the Headworks is pumped to Primary Clarifier Distribution Box where it flows over one of three weirs to each of the Primary Clarifiers. Flow from the primary clarifiers is combined in the Primary Effluent Junction Box, where it is mixed with Return Activated Sludge (RAS) pumped from the secondary clarifiers.

Primary effluent and RAS flow by gravity through a 42-in diameter reinforced concrete pipe to the aeration basins. During ADWF, all flow will be routed to a single aeration basin train. Flow enters the aeration basins through a 36-in downward opening sluice gate. The basins operate in a wrap-around configuration with an internal MLR. Mixed liquor exits the center aeration basins through a 36-in gate and is conveyed by gravity to the Secondary Clarifier Distribution Box through a 30-in diameter concrete pipe.

Mixed liquor is split in the Secondary Clarifier Distribution Box by a series of weirs dedicated to each of the five secondary clarifiers. The new distribution box will consist of five weirs. Two of the five weirs are 7-ft long to feed new Secondary Clarifiers No. 1 and No. 2; the remaining three weirs are 2.5-ft long to feed existing Secondary Clarifiers No. 3, No. 4, and No. 5. This allows more flow to enter the larger 65-ft diameter clarifiers.


Flow feeding Secondary Clarifier No. 2 cascades over the weir and enters a drop box that feeds a 36-IN pipe. The pipe enters the clarifier through the center well, and exits through a peripheral v-notch weir. The effluent launders feed a drop box and 36-IN effluent pipe.



NOTES:

- ENERGY GRADE LINE ELEVATIONS ARE SHOWN AS FOLLOWS:  
 — PEAK WET WEATHER FLOW (PWWF)  
 — MAXIMUM DAY FLOW (MDF)  
 — MAXIMUM MONTH FLOW (MMF)  
 — AVERAGE DRY WEATHER FLOW (ADWF)
- FLows ABOVE 12 MGD WILL BYPASS THE PRIMARY CLARIFIERS.
- REFER TO FIGURES 15-1 AND 15-2 FOR THE FLOW PATH OF EACH SCENARIO.
- REFER TO TABLE 15-1 FOR INFLUENT, RAS, MLR, AND EFFLUENT FLOW RATES IN EACH FLOW SCENARIO.
- REFER TO TABLE 15-2 FOR THE NUMBER OF PROCESS UNITS ONLINE IN EACH FLOW SCENARIO.
- WATER SURFACE ELEVATIONS IN THE INFLUENT PUMP STATION ARE DICTATED BY PUMP LEVEL CONTROL. REFER TO TM 5/6 FOR ADDITIONAL DETAILS ON THE HEADWORKS HYDRAULICS.

PINOLE/HERCULES WPCP PROJECT  
HYDRAULIC PROFILE



C:\pwworking\src\d0436859\FIGURE 15-3.dwg  
03-01-13 RNT/01 12:12:02

Figure 15-3

Secondary effluent combined from all clarifiers enters a 42-in common header and is conveyed to the Chlorine Contact Basin for disinfection. Following disinfection, treated effluent passes over an effluent weir and into a 36-in effluent pipe to the Outfall Junction Structure. From the Outfall Junction Structure flows are diverted to the Effluent Pump Station or to the Emergency Outfall.

## MMF and MDF Scenarios

The MMF and MDF scenarios are operated in a similar fashion the ADWF scenario; however, two aeration basins are online, as well as all primary and Secondary Clarifiers and both Chlorine Contact Basins. In the MDF scenario the RAS recycle is reduced to 50 percent of the influent flow as listed in Table 15-1.

## PWWF Scenario

Figure 15-2 illustrates the flow path for the PWWF scenario. At PWWF the influent flow exceeds the hydraulic capacity of the primary clarifiers. Approximately 12 mgd will pass through the primary clarifiers and the remaining 8 mgd will flow from the Headworks directly to the Primary Effluent Junction Box. The biological treatment process will change to operate in contact stabilization mode.

In contact stabilization mode, RAS will be pumped directly to the aeration basins rather than to the Primary Effluent Junction Box. RAS will enter Aeration Basin Zone 1 through the existing 36-in downward opening sluice gate. Primary Effluent will flow through the 42-in diameter pipe, and enter the mixed liquor channel for Aeration Basin 3. Metal stop gates will be reconfigured so flow is conveyed down the existing step feed channel between Aeration Basins 1 and 2 and Aeration Basins 3 and 4. Flow will exit the step feed ports into Zones D and E. Aeration Basin zones are described in more detail TM 8. At PWWF the MLR pumps will be turned off and no internal recycle will occur.

Flow exits the aeration basins through the 36-in sluice gate and enters the Secondary Clarifier Distribution Box. To provide adequate flow split at PWWF, the weirs in the distribution box will be set at 110.00-ft. This analysis assumes the existing secondary clarifier weirs will be reinstalled, and the invert elevation raised 1.5-in to 109.3-ft. Flow follows the same path as described in the ADWF scenario for the remainder of the treatment process.

## Recommended Project

Output from the Visual Hydraulics model is presented in Appendix B. The construction of a new Secondary Clarifier Distribution Box and two new Secondary Clarifiers will allow the WPCP to operate at all flow scenarios with no hydraulic issues. At least 1-ft of clearance between the water surface elevation and the top of the concrete is provided for each process unit at all flow conditions. The invert of the primary clarifier weirs is adequate; however, HDR recommends that the elevation be field verified as part of the construction project. Table 15-4 provides a list of design considerations for each hydraulic unit process.

*Table 15-4. Unit Process Design Constraints*

| Unit Process                       | Comment  |
|------------------------------------|--|
| Primary Clarifier Distribution Box | <ul style="list-style-type: none"> <li>No modifications necessary</li> </ul>   |
| Primary Clarifiers                 | <ul style="list-style-type: none"> <li>Weir elevations field verified and reset if needed</li> <li>By-pass flows at 12 mgd</li> </ul>  |
| Primary Effluent Junction Box      | <ul style="list-style-type: none"> <li>Junction box provides mixing of RAS and primary effluent prior to biological treatment</li> <li>At PWWFs RAS will not enter the junction box</li> </ul>   |
| Aeration Basins                    | <ul style="list-style-type: none"> <li>Step feed ports will need to be open/retrofitted</li> <li>Operates in contact stabilization mode at during large storm events</li> <li>RAS pumped to Zone A</li> <li>Primary effluent enters basin at Zone D/E</li> <li>30-IN effluent pipe will be replaced with 36-IN pipe to minimize headloss.</li> </ul> |
| Secondary Effluent Junction Box    | <ul style="list-style-type: none"> <li>New box will provide correct flow split to five secondary clarifiers</li> <li>New box will limit the headloss through the secondary system</li> </ul>   |
| Secondary Clarifiers               | <ul style="list-style-type: none"> <li>Weir elevations will be raised to 109.30-FT, to handle 20 mgd</li> <li>Two new 65-FT diameter clarifiers will be constructed to handle 60 percent of the flow.</li> </ul>   |
| Chlorine Contact Basin             | <ul style="list-style-type: none"> <li>Re-use existing infrastructure, no hydraulic modifications</li> </ul>   |

There are no costs included in this TM for the recommended improvements. The costs for the discussed improvements are included in the TMs for the associated treatment process.

DRAFT

## Appendix A. Pinole/Hercules WPCP Hydraulic Element List

DRAFT

**HYDRAULIC ELEMENTS LIST -ADWF**  
**Pinole/Hercules WPCP Predesign**

| FACILITY                             | DWG. NO.                           | COMPONENT                                  | ELEVATIONS* |                 |             | DIMENSIONS |          |          |               |                   | LOSSES              | FLOW  |                        |          |             |          |             | COMMENTS/OPERATION |   |
|--------------------------------------|------------------------------------|--|-------------|-----------------|-------------|------------|----------|----------|---------------|-------------------|---------------------|---|------------------------|----------|-------------|----------|-------------|--------------------|---|
|                                      |                                    |  | WSE (ft)    | TOP / ROOF (ft) | INVERT (ft) | LENGTH     | DIAMETER | WIDTH    | SLOPE (ft/ft) | DEPTH             |                     | Average Dry Weather Flow  |                        |          |             |          |             |                    |   |
|                                      |                                    |  |             |                 |             |            |          |          |               |                   |                     | FORWARD FLOW  | PERCENT (%)            | RAS FLOW | PERCENT (%) | MLS FLOW | PERCENT (%) |                    |   |
| Chlorine Contact Basin               | 2002 SC G-4                        | Effluent Weir                              | 107.71      |                 | 107.15      | 4.50       |          |          |               |                   |                     | 6 - 180 deg Bends<br>1-90 deg Bend                                | 2.03                   | 50%      |             |          |             |                    |   |
|                                      | 1971 WPCF M-55.4                   | Basin                                      | 107.72      | 110.50          | 103.25      | 140.0 ft   |          | 4.0 ft   |               |                   |                     |   | 2.03                   | 50%      |             |          |             |                    |   |
|                                      | 1971 WPCF M-55.4                   | Slide Gate                                 |             |                 | 103.25      |            |          | 24.0 in  |               | 36.0 in           |                     |   | 2.03                   | 50%      |             |          |             |                    |   |
|                                      | 1971 WPCF M-55.4                   | Influent Box                               | 107.73      |                 | 103.25      | 8.0 ft     |          | 4.0 ft   |               |                   |                     |   | 4.06                   | 100%     |             |          |             |                    |   |
|                                      | Figure C                           | 42 - IN SCE                                |             |                 |             | 116.0 ft   |          | 42.0 in  |               |                   |                     |   | 3-90 deg bends<br>Exit | 4.06     | 100%        |          |             |                    |   |
| Figure C                             | SC #1 Effluent Connection          | 107.75                                     |             |                 |             |            | 24.0 in  |          |               |                   |                     | Wye 24" to 42"  |                        |          |             |          |             |                    |   |
| Secondary Clarifier # 1              | Not yet produced                   | SC # 1 30" Effluent Pipe                   |             |                 |             | 70 ft      |          | 30.0 in  |               |                   |                     | Entrance 2-90 deg Bends   | 1.22                   | 30%      |             | 30%      |             |                    | 30% to each new SC (1,2),<br>14% to each old SC (3,4,5)           |
|                                      |                                    | SC # 1 Effluent Box                        |             |                 | 90          | 4 ft       |          | 4 ft     |               |                   |                     |   |                        |          |             |          |             |                    |   |
|                                      |                                    | SC # 1 Effluent Launder                    | 107.84      |                 | 107         | 100 ft     |          | 1.0 ft   | 0.004         |                   |                     |   | 0.61                   | 15%      |             | 30%      |             |                    |   |
|                                      | Weir Elev. Increased by 4"         | SC # 1 Effluent Weir                       | 109.37      |                 | 109.3       |            |          |          |               |                   |                     |   | 1.22                   | 30%      |             | 30%      |             |                    |   |
|                                      |                                    | SC #1                                      | 109.37      | 112.00          | 90.00       |            | 65.0 ft  |          | 0.00522222    | 22.5 ft -22.03 ft |                     |   | 1.22                   | 30%      | 0.97        | 30%      |             |                    |   |
|                                      |                                    | SC # 1 Inlet Ports                         |             | 109.8 ft        | 106.00 ft   |            |          | 0.5 ft   |               | 2.5 ft            |                     | 6 Inlet ports<br>2 - 90 deg bends<br>5 - 45 deg bends<br>Entrance | 1.22                   | 30%      | 0.97        | 30%      |             |                    |   |
| Secondary Clarifier Distribution Box | See TM                             | SC #2 Influent Box                         | 109.39      | 113.50          | 100.00      | 3.0 ft     |          | 7.5      |               |                   |                     | High headloss over short weir                                     | 1.22                   | 30%      | 0.97        | 30%      |             |                    |   |
|                                      | See TM                             | Submerged Weir SC 5 Dist. Box Weir         | 110.28      |                 | 110.00      | 7.0 ft     |          |          |               |                   |                     |   | 1.22                   | 30%      | 0.97        | 30%      |             |                    |   |
|                                      | See TM                             | SC Distribution Box                        | 110.28      | 113.50          | 100.00      | 9.0 ft     |          | 30.0 ft  |               |                   |                     |   | 4.06                   | 100%     | 3.25        | 100%     |             |                    | New splitter box required,  |
| AB # 3,4                             | Not yet produced                   | AB No. 3 36-IN Effluent                    |             |                 |             | 5.0 ft     |          | 36.0 in  |               |                   |                     | exit<br>2 - 11.25 deg bends<br>entrance                           | 4.06                   | 100%     | 3.25        | 100%     |             |                    |   |
|                                      | Not yet produced                   | AB No. 3 36-IN Gate                        |             |                 | 105.50      |            |          | 36.0 in  |               |                   |                     |   |                        |          |             |          |             |                    |   |
|                                      | 1983 Exp. S-4                      | AB 3 ML Drop Box                           | 110.46      | 113.5 ft        | 105.5 ft    | 3.0 ft     |          | 3.0 ft   |               | 5.5 ft            |                     |   | 4.06                   | 100%     | 3.25        | 100%     |             |                    |   |
|                                      | 1983 Exp. S-4                      | AB 3 ML Effluent Channel                   | 110.47      |                 | 109.25 ft   | 5.5 ft     |          | 3.0 ft   |               | 4.3 ft            |                     |   | 4.06                   | 100%     | 3.25        | 100%     |             |                    | High headloss   |
|                                      | 1983 Exp. M-7                      | AB No. 3 - Effluent Sluice Gate            |             |                 | 109.25 ft   | --         |          | 36.0 in  |               | 30.0 in           |                     |   | 4.06                   | 100%     | 3.25        | 100%     |             |                    | Oriface DS control  |
|                                      | Figure 10                          | AB No. 3 Zone E                            | 110.57      |                 | 96.5 ft     | 95.0 ft    |          | 20.0 ft  |               | 17.0 ft           |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               | 190' is total length of Abs.                                      |
|                                      | Figure 10                          | Baffle Zone E to D                         |             |                 | 109.0 ft    | --         |          | 20.0 ft  |               | --                |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | Figure 10                          | AB No. 3 Zone D                            | 110.60      |                 | 96.5 ft     | 95.0 ft    |          | 20.0 ft  |               | 17.0 ft           |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | Figure 10                          | Baffle Zone D to C                         |             |                 | 109.0 ft    | --         |          | 20.0 ft  |               | --                |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | Figure 10                          | AB No. 4 Zone C                            | 110.63      |                 | 96.5 ft     | 130.0 ft   |          | 20.0 ft  |               | 17.0 ft           |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | Figure 10                          | Baffle Zone C to B                         |             |                 | 109.0 ft    | --         |          | 20.0 ft  |               | --                |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | Figure 10                          | AB No. 4. Zone B                           | 110.66      |                 | 96.5 ft     | 30.0 ft    |          | 20.0 in  |               | 17.0 in           |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | Figure 10                          | Baffle Zone B to A                         |             |                 | 109.0 ft    | --         |          | 20.0 ft  |               | --                |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | 1983 Exp. S-4                      | AB 4 Zone A                                | 110.69      |                 | 96.5 ft     | 30.0 ft    |          | 20.0 ft  |               | 17.0 ft           |                     |   | 4.06                   | 100%     | 3.25        | 100%     | 8.12        | 100%               |   |
|                                      | 1983 Exp. M-7                      | AB No. 4 - Influent Sluice Gate            |             |                 | 110.00 ft   | --         |          | 36.0 in  |               | 30.0 in           |                     | 3 gates   | 4.06                   | 100%     | 3.25        | 100%     |             |                    |   |
|                                      | 1983 Exp. S-4                      | AB No. 4 Influent Channe                   | 110.72      |                 | 109.25 ft   | 4.0 ft     |          | 3.0 ft   |               | 4.0 ft            |                     |   | 4.06                   | 100%     | 3.25        | 100%     |             |                    |   |
| 1983 Exp. S-4                        | AB No. 4 Sloped Channel            |  |             | 109.25 ft       | 5.3 ft      |            | 3.0 ft   | 0.141 ft |               |                   |                     | 4.06  | 100%                   | 3.25     | 100%        |          |             |                    |   |
| 1983 Exp S-5                         | AB No. 3/4 Splitter Box/Channel    | 110.83                                     |             | 110.0 ft        | 12.0 ft     |            | 4.5 ft   |          | 3.0 ft        |                   |                     | 4.06  | 100%                   | 3.25     | 100%        |          |             | High headloss      |   |
| 1983 Exp.                            | 42-IN RCP Influent Pipe AB No. 3/4 |  |             |                 | 58.0 ft     |            | 42.0 in  |          |               |                   |                     | exit<br>2 - 90 deg bends  | 4.06                   | 100%     | 3.25        | 100%     |             |                    |   |
| 1983 Exp.                            | 42-IN RCP Tee Line to Branch       | 110.88                                     |             |                 |             |            | 42.0 in  |          |               |                   |                     | Tee   | 4.06                   | 100%     | 3.25        | 100%     |             |                    |   |
| Primary Effluent Junction on Box     | 1971 EXP M 30.2                    | 42-IN RCP PC Effluent Pipe to Junction Box |             |                 |             | 224 ft     |          | 45.0 in  |               |                   |                     |   | 4.06                   | 100%     | 3.248       | 100%     |             |                    |   |
|                                      | 1971 EXP M 30.2                    | PE Junction Box                            | 111.03      | 114.5 ft        | 104.5 ft    | 16.5 ft    |          | 7.0 ft   |               | 10.0 ft           |                     |   | 4.06                   | 100%     | 3.248       | 100%     |             |                    | May cause hydraulic issues if SC Dist. Box Weir Elve. is raised   |
| Primary Clarifier #2                 | 1983 - S.2                         | PC # 2 24 -IN RCP Effluent                 |             |                 |             | 120        |          |          |               |                   |                     | 4-45 deg bends<br>2-90 deg bends<br>exit                          | 1.34                   | 33%      |             |          |             |                    | Pipe assumed to go all the way to the new PC#3                    |
|                                      | 1971 WPCF M 30.1                   | PC # 2 Effluent Box                        | 111.03      | 116.00          | 112.00      | 4          |          | 1.5 ft   |               |                   |                     |   | 1.34                   | 33%      |             |          |             |                    |   |
|                                      | 1971 WPCF M 30.1                   | PC # 2 Effluent Trough/Launder             |             |                 | 112.00      | 78         |          | 1.0 ft   | -0.0094       |                   |                     |   | 0.67                   | 17%      |             |          |             |                    |   |
|                                      | 2002 SC G4                         | PC # 2 Effluent Weir                       |             |                 | 114.25      | 135        |          |          |               |                   |                     |   | 1.34                   | 33%      |             |          |             |                    | V-notch weir 8" Spacing 90 deg angle, 212 notches Invert = 114.25 |
|                                      | 1971 WPCF M 30.1                   | PC # 2 Basin                               | 114.36      |                 | 106.00      |            | 45.0 ft  |          |               |                   |                     |   | 1.34                   | 33%      |             |          |             |                    |   |
|                                      | 1971 WPCF M 30.1                   | PC # 2 18-IN Influent wel                  |             |                 |             | 7 ft       | 18.0 in  |          |               |                   |                     |   |                        |          |             |          |             |                    |   |
|                                      | 1971 WPCF M 30.1                   | PC # 2 24-In Influent                      |             |                 |             | 18 ft      | 24.0 in  |          |               |                   |                     | 90 bend Bend<br>Exit<br>Reducer 36" to 24"                        | 1.34                   | 33%      |             |          |             |                    |   |
| 1971 WPCF M 30.1                     | 36-In Influent pipe                |  |             |                 | 32 ft       | 36.0 in    |          |          |               |                   | 90 Bend<br>Entrance | 1.34  | 33%                    |          |             |          |             |                    |   |
| PC Flow Split Structure              | 1971 WPCF M 30.1                   | Drop Box to Primary Clarifier No.2         | 114.42      |                 |             | 40.0 in    |          | 40.0 in  |               |                   |                     |   | 1.34                   | 33%      |             |          |             |                    |   |
|                                      | 1971 WPCF M 30.2                   | Primary Clarifier Distribution Box Weir    | 117.32      | 120.00          | 117.00      | 4.0 ft     |          |          |               |                   |                     |   | 1.34                   | 33%      |             |          |             |                    | Flow is pumped to this location.                                  |

\*All elevations on the 1929 Datum per 1971 WPCF Drawings

**Drawing Sets Used to Develop Hydraulic Elements List**

| YEAR | DRAWING SET                               | Abbr.     |
|------|---|-----------|
| 2002 | B&C Secondary Clarifier # 5 Expansion     | 2002 SC   |
| 1983 | M&E Plant Expansion                       | 1983 Exp. |
| 1971 | Yoder - Trotter - Orlob & Associates WPCF | 1971 WPCF |

**Input Flows**

| YEAR | CONDITION           | FLOW (MGD) |       |       |
|------|---------------------|------------|-------|-------|
|      |                     | INFLUENT   | RAS   | MLR   |
| 2010 | Average             | 4.05       | 3.85  | --    |
|      | Peak Wet Weather    | 10.00      | 5.00  | --    |
| 2030 | Average Dry Weather | 4.06       | 3.25  | 8.12  |
|      | Maximum Month       | 6.09       | 4.87  | 12.18 |
|      | Maximum Day         | 11.30      | 10.74 | 13.56 |
|      | Peak Wet Weather    | 20.00      | 10.00 | 5.50  |

**HYDRAULIC ELEMENTS LIST - MM**  
Pinole/Hercules WPCF Predesign

| FACILITY                             | DWG. NO.                  | COMPONENT                                  | ELEVATIONS* |                 |             | DIMENSIONS |          |         |               |                    | LOSSES  | FLOW           |             |          |             |          |             | COMMENTS/OPERATION  |
|--------------------------------------|---------------------------|--|-------------|-----------------|-------------|------------|----------|---------|---------------|--------------------|---------|----------------|-------------|----------|-------------|----------|-------------|---|
|                                      |                           |  | WSE (ft)    | TOP / ROOF (ft) | INVERT (ft) | LENGTH     | DIAMETER | WIDTH   | SLOPE (ft/ft) | DEPTH              |         | Max Month Flow |             |          |             |          |             |   |
|                                      |                           |  |             |                 |             |            |          |         |               |                    |         | FORWARD FLOW   | PERCENT (%) | RAS FLOW | PERCENT (%) | MLS FLOW | PERCENT (%) |   |
| Chlorine Contact Basin               | 2002 SC G-4               | Effluent Weir                              |             |                 | 107.15      | 4.50       |          |         |               |                    |         | 3.045          | 50%         |          |             |          |             |   |
|                                      | 1971 WPCF M-55            | Basin                                      |             | 110.50          | 103.25      | 140.0 ft   |          | 4.0 ft  |               |                    |         | 3.045          | 50%         |          |             |          |             |   |
|                                      | 1971 WPCF M-55            | Slide Gate                                 |             |                 | 103.25      |            |          | 24.0 in |               |                    | 36.0 in |                | 3.045       | 50%      |             |          |             |   |
|                                      | 1971 WPCF M-55            | Influent Box                               |             |                 | 103.25      | 8.0 ft     |          | 4.0 ft  |               |                    |         | 6.09           | 100%        |          |             |          |             |   |
|                                      | Figure C                  | 42 - IN SCE                                |             |                 |             | 116.0 ft   | 42.0 in  |         |               |                    |         | 6.09           | 100%        |          |             |          |             |   |
| Figure C                             | SC #1 Effluent Connection |  |             |                 |             |            | 24.0 in  |         |               |                    |         |                |             |          |             |          |             |   |
| Secondary Clarifier # 1              | Not yet produced          | SC # 1 30" Effluent Pipe                   |             |                 |             | 70 ft      | 30.0 in  |         |               |                    |         |                |             |          |             |          |             |   |
|                                      |                           | SC # 1 Effluent Box                        |             |                 | 90          | 4 ft       |          | 4 ft    |               |                    |         | 1.83           | 30%         |          | 30%         |          |             |   |
|                                      |                           | SC # 1 Effluent Launder                    |             |                 | 100         | 100 ft     |          | 1.0 ft  | 0.004         |                    |         | 0.91           | 15%         |          | 30%         |          |             |   |
|                                      | Weir Elv. Increased by 4" | SC # 1 Effluent Weir                       |             |                 | 200         |            |          |         |               |                    |         | 1.83           | 30%         |          | 30%         |          |             |   |
|                                      |                           | SC #1                                      |             | 112.00          | 90.00       |            | 65.0 ft  |         | 0.00522222    | 22.5 ft - 22.03 ft |         | 1.83           | 30%         | 1.46     | 30%         |          |             |   |
|                                      |                           | SC # 1 Inlet Ports                         |             | 109.8 ft        | 106.00 ft   |            |          | 0.5 ft  |               | 2.5 ft             |         | 1.83           | 30%         | 1.46     | 30%         |          |             |   |
|                                      |                           | SC #1 Influent Line                        |             | --              |             | 200 ft     | 24.0 in  |         |               |                    |         | 1.83           | 30%         | 1.46     | 30%         |          |             |   |
| Secondary Clarifier Distribution Box | See TM                    | SC # 1 Influent Box                        |             | 113.50          | 100.00      | 3.0 ft     |          | 7.5     |               | 13.5 ft            |         | 1.83           | 30%         | 1.46     | 30%         |          |             |   |
|                                      | See TM                    | Weir to SC #1                              |             |                 | 110.00      | 7.0 ft     |          |         |               |                    |         | 1.83           | 30%         | 1.46     | 30%         |          |             |   |
|                                      | See TM                    | SC Distribution Box                        |             | 113.50          | 100.00      | 9.0 ft     |          | 30.0 ft |               | 13.50 ft           |         | 6.09           | 100%        | 4.87     | 100%        |          |             | New splitter box required,                                      |
| AB # 3,4                             | Not yet produced          | AB No. 3 36-IN Effluent                    |             |                 |             | 5.0 ft     | 36.0 in  |         |               |                    |         |                |             |          |             |          |             |   |
|                                      | Not yet produced          | AB No. 3 36-IN Gate                        |             |                 | 105.50      |            | 36.0 in  |         |               |                    |         | 3.045          | 50%         | 2.436    | 50%         |          |             |   |
|                                      | 1983 Exp. S-4             | AB 3 ML Drop Box                           |             | 113.5 ft        | 105.5 ft    | 3.0 ft     |          | 3.0 ft  |               | 5.5 ft             |         | 3.045          | 50%         | 2.436    | 50%         |          |             |   |
|                                      | 1983 Exp. S-4             | AB 3 ML Effluent Channel                   |             |                 | 109.25 ft   | 5.5 ft     |          | 3.0 ft  |               | 4.3 ft             |         | 3.045          | 50%         | 2.436    | 50%         |          |             | High headloss   |
|                                      | 1983 Exp. M-7             | AB No. 3 - Effluent Sluice Gate            |             |                 | 109.25 ft   | --         |          | 36.0 in |               | 30.0 in            |         | 3.045          | 50%         | 2.436    | 50%         |          |             | Oriface DS control  |
|                                      | Figure 10                 | AB No. 3 Zone E                            |             |                 | 96.5 ft     | 95.0 ft    |          | 20.0 ft |               | 17.0 ft            |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         | 190' is total length of Abs.                                    |
|                                      | Figure 10                 | Baffle Zone E to D                         |             |                 | 109.0 ft    | --         |          | 20.0 ft |               | --                 |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         |   |
|                                      | Figure 10                 | AB No. 3 Zone D                            |             |                 | 96.5 ft     | 95.0 ft    |          | 20.0 ft |               | 17.0 ft            |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         |   |
|                                      | Figure 10                 | Baffle Zone D to C                         |             |                 | 109.0 ft    | --         |          | 20.0 ft |               | --                 |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         | During MM flow conditions, 100% of influent is sent to          |
|                                      | Figure 10                 | AB No. 4 Zone C                            |             |                 | 96.5 ft     | 130.0 ft   |          | 20.0 ft |               | 17.0 ft            |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         | Aeration Basins, 90% is   |
|                                      | Figure 10                 | Baffle Zone C to B                         |             |                 | 109.0 ft    | --         |          | 20.0 ft |               | --                 |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         | RAS, and 145% is MLR.   |
|                                      | Figure 10                 | AB No 4. Zone B                            |             |                 | 96.5 ft     | 30.0 ft    |          | 20.0 in |               | 17.0 in            |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         |   |
|                                      | Figure 10                 | Baffle Zone B to A                         |             |                 | 109.0 ft    | --         |          | 20.0 ft |               | --                 |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         |   |
|                                      | 1983 Exp. S-4             | AB 4 Zone A                                |             |                 | 96.5 ft     | 30.0 ft    |          | 20.0 ft |               | 17.0 ft            |         | 3.045          | 50%         | 2.436    | 50%         | 6.09     | 50%         |   |
|                                      | 1983 Exp. M-7             | AB No. 4 - Influent Sluice Gate            |             |                 | 110.00 ft   | --         |          | 36.0 in |               | 30.0 in            |         | 3.045          | 50%         | 2.436    | 50%         |          |             | 3 gates modeled @ Inv 110.004                                   |
|                                      | 1983 Exp. S-4             | AB No. 4 Influent Channel                  |             |                 | 109.25 ft   | 4.0 ft     |          | 3.0 ft  |               | 4.0 ft             |         | 3.045          | 50%         | 2.436    | 50%         |          |             |   |
|                                      | 1983 Exp. S-4             | AB No. 4 Sloped Channel                    |             |                 | 109.25 ft   | 5.3 ft     |          | 3.0 ft  | 0.141 ft      |                    |         | 3.045          | 50%         | 2.436    | 50%         |          |             |   |
|                                      | 1983 Exp S-5              | AB No. 3/4 Splitter Box/Channel            |             |                 | 110.0 ft    | 12.0 ft    |          | 4.5 ft  |               | 3.0 ft             |         | 3.045          | 50%         | 2.436    | 50%         |          |             | High headloss   |
|                                      | 1983 Exp.                 | 42-IN RCP Influent Pipe AB No. 3/4         |             |                 |             | 58.0 ft    | 42.0 in  |         |               |                    |         | 3.045          | 50%         | 2.436    | 50%         |          |             |   |
|                                      | 1983 Exp.                 | 42-IN RCP Tee Line to Branch               |             |                 |             |            | 42.0 in  |         |               |                    |         | 3.045          | 50%         | 2.436    | 50%         |          |             |   |
| Primary Effluent Junction Box        | 1971 EXP M 30.2           | 42-IN RCP PC Effluent Pipe to Junction Box |             |                 |             | 224 ft     | 45.0 in  |         |               |                    |         | 6.09           | 100%        | 4.872    | 100%        |          |             | May cause hydraulic issues if SC Dist. Box Weir Elve. Is raised |
|                                      | 1971 EXP M 30.2           | PE Junction Box                            |             | 114.5 ft        | 104.5 ft    | 16.5 ft    |          | 7.0 ft  |               | 10.0 ft            |         | 6.09           | 100%        | 4.872    | 100%        |          |             |   |
| Primary Clarifier #2                 | 1983 - S.2                | PC # 2 24 -IN RCP Effluent                 |             |                 |             | 120        |          |         |               |                    |         | 2.01           | 33%         |          |             |          |             | Pipe assumed to go all the                                      |
|                                      | 1971 WPCF M 30            | PC # 2 Effluent Box                        |             | 116.00          | 112.00      | 4          |          | 1.5 ft  |               |                    |         | 2.01           | 33%         |          |             |          |             |   |
|                                      | 1971 WPCF M 30            | PC # 2 Effluent Trough/Launder             |             |                 | 112.00      | 78         |          | 1.0 ft  | -0.0094       |                    |         | 1.00           | 17%         |          |             |          |             |   |
|                                      | 2002 SC G4                | PC # 2 Effluent Weir                       |             |                 | 114.25      | 135        |          |         |               |                    |         | 2.01           | 33%         |          |             |          |             | V-notch weir 8" Spacing 90 deg angle, 212 notches               |
|                                      | 1971 WPCF M 30            | PC # 2 Basin                               |             |                 | 106.00      |            | 45.0 ft  |         |               |                    |         | 2.01           | 33%         |          |             |          |             |   |
|                                      | 1971 WPCF M 30            | PC # 2Influent well                        |             |                 |             | 7 ft       | 18.0 in  |         |               |                    |         | 2.01           | 33%         |          |             |          |             |   |
|                                      | 1971 WPCF M 30            | PC # 2 24-In Influent                      |             |                 |             | 18 ft      | 24.0 in  |         |               |                    |         | 2.01           | 33%         |          |             |          |             |   |
| 1971 WPCF M 30                       | 36-In Influent pipe       |  |             |                 | 32 ft       | 36.0 in    |          |         |               |                    | 2.01    | 33%            |             |          |             |          |             |   |
| PC Flow Split Structure              | 1971 WPCF M 30            | Drop Box to Primary Clarifier No.2         |             |                 | 108.00      | 40.0 in    | 40.0 in  |         |               |                    |         | 2.01           | 33%         |          |             |          |             |   |
|                                      | 1971 WPCF M 30            | Primary Clarifier Distribution Box Weir    |             | 120.00          | 117.00      | 4.0 ft     |          |         |               |                    |         | 2.01           | 33%         |          |             |          |             | Flow is pumped to this location.                                |

\*All elevations on the 1929 Datum per 1971 WPCF Drawings

**Drawing Sets Used to Develop Hydraulic Elements List**

| YEAR | DRAWING SET                               | Abbr.     |
|------|---|-----------|
| 2002 | B&C Secondary Clarifier # 5 Expansion     | 2002 SC   |
| 1983 | M&E Plant Expansion                       | 1983 Exp. |
| 1971 | Yoder - Trotter - Orlob & Associates WPCF | 1971 WPCF |

**Input Flows**

| YEAR | CONDITION        | FLOW (MGD) |       |       |
|------|------------------|------------|-------|-------|
|      |                  | INFLUENT   | RAS   | MLR   |
| 2010 | Average          | 4.05       | 3.85  | --    |
|      | Peak Wet Weather | 10.00      | 5.00  | --    |
| 2030 | Maximum Month    | 6.09       | 4.87  | 12.18 |
|      | Maximum Day      | 11.30      | 10.74 | 13.56 |
|      | Peak Wet Weather | 20.00      | 10.00 | 5.50  |

**HYDRAULIC ELEMENTS LIST - MD**  
**Pinole/Hercules WPCP Predesign**

| FACILITY                             | DWG. NO.                           | COMPONENT                                  | ELEVATIONS* |                 |             | DIMENSIONS |          |         |               |                   | LOSSES        | FLOW         |                                   |          |             |          |             | COMMENTS/OPERATION |                                  |
|--------------------------------------|------------------------------------|--|-------------|-----------------|-------------|------------|----------|---------|---------------|-------------------|---------------|--------------|-----------------------------------|----------|-------------|----------|-------------|--------------------|----------------------------------|
|                                      |                                    |  | WSE (ft)    | TOP / ROOF (ft) | INVERT (ft) | LENGTH     | DIAMETER | WIDTH   | SLOPE (ft/ft) | DEPTH             |               | Max Day Flow |                                   |          |             |          |             |                    |                                  |
|                                      |                                    |  |             |                 |             |            |          |         |               |                   |               | FORWARD FLOW | PERCENT (%)                       | RAS FLOW | PERCENT (%) | MLS FLOW | PERCENT (%) |                    |                                  |
| Chlorine Contact Basin               | 2002 SC G-4                        | Effluent Weir                              |             |                 | 107.15      | 4.50       |          |         |               |                   |               |              | 5.65                              | 50%      |             |          |             |                    |                                  |
|                                      | 1971 WPCF M-54                     | Basin                                      |             | 110.50          | 103.25      | 140.0 ft   |          | 4.0 ft  |               |                   |               |              | 5.65                              | 50%      |             |          |             |                    |                                  |
|                                      | 1971 WPCF M-54                     | Slide Gate                                 |             |                 | 103.25      |            |          | 24.0 in |               |                   | 36.0 in       |              | 5.65                              | 50%      |             |          |             |                    |                                  |
|                                      | 1971 WPCF M-54                     | Influent Box                               |             |                 | 103.25      | 8.0 ft     |          | 4.0 ft  |               |                   |               |              | 11.3                              | 100%     |             |          |             |                    |                                  |
|                                      | Figure C                           | 42 - IN SCE                                |             |                 |             | 116.0 ft   | 42.0 in  |         |               |                   |               |              | 11.3                              | 100%     |             |          |             |                    |                                  |
| Figure C                             | SC #1 Effluent Connection          |  |             |                 |             |            | 36.0 in  |         |               |                   |               |              |                                   |          |             |          |             |                    |                                  |
| Secondary Clarifier # 1              | Not yet produced                   | SC # 1 36" Effluent Pipe                   |             |                 |             | 70 ft      | 36.0 in  |         |               |                   |               |              | Entrance 2-90 deg Bends           | 3.39     | 30%         |          | 30%         |                    |                                  |
|                                      |                                    | SC # 1 Effluent Box                        |             |                 | 90          | 4 ft       |          | 4 ft    |               |                   |               |              |                                   | 3.39     | 30%         |          |             |                    |                                  |
|                                      |                                    | SC # 1 Effluent Launder                    |             |                 | 107         | 100 ft     |          | 1.0 ft  | 0.004         |                   |               |              |                                   | 3.39     | 30%         |          |             |                    |                                  |
|                                      | Weir Elv.                          | SC # 1 Effluent Weir                       |             |                 | 109.3       |            |          |         |               |                   |               |              |                                   | 1.70     | 15%         |          | 15%         |                    |                                  |
|                                      |                                    | SC #1                                      |             | 112.00          | 90.00       |            | 65.0 ft  |         | 0.00522222    | 22.5 ft -22.03 ft |               |              |                                   | 3.39     | 30%         |          | 30%         |                    |                                  |
|                                      |                                    | SC # 1 Inlet Ports                         | 109.8 ft    | 106.00 ft       |             |            | 0.5 ft   |         |               | 2.5 ft            | 6 Inlet ports | 3.39         | 30%                               | 2.71     | 30%         |          |             |                    |                                  |
|                                      | SC #1 Influent Line                | --   |             |                 | 200 ft      | 36.0 in    |          |         |               | 3-45 bends        | 3.39          | 30%          | 2.71                              | 30%      |             |          |             |                    |                                  |
|                                      |                                    |  |             |                 |             |            |          |         |               |                   |               |              | 3.39                              | 30%      | 2.71        | 30%      |             |                    |                                  |
| Secondary Clarifier Distribution Box | See TM                             | SC #2 Influent Box                         |             | 113.50          | 100.00      | 3.0 ft     |          | 7.5     |               | 13.5 ft           |               |              |                                   | 3.39     | 30%         | 2.71     | 30%         |                    |                                  |
|                                      | See TM                             | Submerged Weir SC 5 Dist. Box Weir         |             |                 | 110.00      | 7.0 ft     |          |         |               |                   |               |              | High headloss over short weir     | 3.39     | 30%         | 2.71     | 30%         |                    |                                  |
|                                      | See TM                             | SC Distribution Box                        |             | 113.50          | 100.00      | 9.0 ft     |          | 30.0 ft |               | 13.50 ft          |               |              |                                   | 11.30    | 100%        | 9.04     | 100%        |                    | New splitter box required.       |
| AB # 3,4                             | Not yet produced                   | AB No. 3 36-IN Effluent                    |             |                 |             | 5.0 ft     | 36.0 in  |         |               |                   |               |              | exit 2 - 11.25 deg bends entrance | 5.65     | 50%         | 4.52     | 50%         |                    |                                  |
|                                      | Not yet produced                   | AB No. 3 36-IN Gate                        |             |                 | 105.50      |            | 36.0 in  |         |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         |                    |                                  |
|                                      | 1983 Exp. S-4                      | AB 3 ML Drop Box                           | 113.5 ft    | 105.5 ft        | 3.0 ft      |            | 3.0 ft   |         | 5.5 ft        |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         |                    |                                  |
|                                      | 1983 Exp. S-4                      | AB 3 ML Effluent Channel                   |             | 109.25 ft       | 5.5 ft      |            | 3.0 ft   |         | 4.3 ft        |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         |                    | High headloss                    |
|                                      | 1983 Exp. M-7                      | AB No. 3 - Effluent Sluice Gate            |             | 109.25 ft       | --          |            | 36.0 in  |         | 30.0 in       |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         |                    | Oriface DS control               |
|                                      | Figure 10                          | AB No. 3 Zone E                            |             | 96.5 ft         | 95.0 ft     | 20.0 ft    |          | 17.0 ft |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | Figure 10                          | Baffle Zone E to D                         |             | 109.0 ft        | --          | 20.0 ft    |          | --      |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | Figure 10                          | AB No. 3 Zone D                            |             | 96.5 ft         | 95.0 ft     | 20.0 ft    |          | 17.0 ft |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | Figure 10                          | Baffle Zone D to C                         |             | 109.0 ft        | --          | 20.0 ft    |          | --      |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | Figure 10                          | AB No. 4 Zone C                            |             | 96.5 ft         | 130.0 ft    | 20.0 ft    |          | 17.0 ft |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | Figure 10                          | Baffle Zone C to B                         |             | 109.0 ft        | --          | 20.0 ft    |          | --      |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | Figure 10                          | AB No 4. Zone B                            |             | 96.5 ft         | 30.0 ft     | 20.0 in    |          | 17.0 in |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | Figure 10                          | Baffle Zone B to A                         |             | 109.0 ft        | --          | 20.0 ft    |          | --      |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | 1983 Exp. S-4                      | AB 4 Zone A                                |             | 96.5 ft         | 30.0 ft     | 20.0 ft    |          | 17.0 ft |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         | 11.3               | 50%                              |
|                                      | 1983 Exp. M-7                      | AB No. 4 - Influent Sluice Gate            |             | 110.00 ft       | --          | 36.0 in    |          | 30.0 in |               |                   | 3 gates       | 5.65         | 50%                               | 4.52     | 50%         |          |             |                    | 3 gates modeled @ Inv 110.004    |
|                                      | 1983 Exp. S-4                      | AB No. 4 Influent Channel                  |             | 109.25 ft       | 4.0 ft      | 3.0 ft     |          | 4.0 ft  |               |                   |               | 5.65         | 50%                               | 4.52     | 50%         |          |             |                    |                                  |
| 1983 Exp. S-4                        | AB No. 4 Sloped Channel            |  | 109.25 ft   | 5.3 ft          | 3.0 ft      |            | 0.141 ft |         |               |                   | 5.65          | 50%          | 4.52                              | 50%      |             |          |             |                    |                                  |
| 1983 Exp S-5                         | AB No. 3/4 Splitter Box/Channel    |  | 110.0 ft    | 12.0 ft         | 4.5 ft      |            | 3.0 ft   |         |               |                   | 5.65          | 50%          | 4.52                              | 50%      |             |          |             | High headloss      |                                  |
| 1983 Exp.                            | 42-IN RCP Influent Pipe AB No. 3/4 |  |             |                 | 58.0 ft     | 42.0 in    |          |         |               |                   |               |              | Exit 2 -90 deg bends Tee          | 5.65     | 50%         | 4.52     | 50%         |                    |                                  |
| 1983 Exp.                            | 42-IN RCP Tee Line to Branch       |  |             |                 |             | 42.0 in    |          |         |               |                   |               |              |                                   | 5.65     | 50%         | 4.52     | 50%         |                    |                                  |
| Primary Effluent Junction Box        | 1971 EXP M 30.2                    | 42-IN RCP PC Effluent Pipe to Junction Box |             |                 |             | 224 ft     | 45.0 in  |         |               |                   |               |              | 2-90deg bends entrance            | 11.30    | 100%        | 9.04     | 100%        |                    |                                  |
|                                      | 1971 EXP M 30.2                    | PE Junction Box                            |             | 114.5 ft        | 104.5 ft    | 16.5 ft    |          | 7.0 ft  |               | 10.0 ft           |               |              |                                   | 11.30    | 100%        | 9.04     | 100%        |                    |                                  |
| Primary Clarifier #2                 | 1983 - S.2                         | PC # 2 24 -IN RCP Effluent                 |             |                 |             | 120        |          |         |               |                   |               |              | 4-45 deg bends                    | 3.73     | 33%         |          |             |                    |                                  |
|                                      | 1971 WPCF M 30                     | PC # 2 Effluent Box                        |             | 116.00          | 112.00      | 4          |          | 1.5 ft  |               |                   |               |              |                                   | 3.73     | 33%         |          |             |                    |                                  |
|                                      | 1971 WPCF M 30                     | PC # 2 Effluent Trough/Launder             |             |                 | 112.00      | 78         |          | 1.0 ft  | -0.0094       |                   |               |              |                                   | 1.86     | 17%         |          |             |                    |                                  |
|                                      | 2002 SC G4                         | PC # 2 Effluent Weir                       |             |                 | 114.25      | 135        |          |         |               |                   |               |              |                                   | 3.73     | 33%         |          |             |                    |                                  |
|                                      | 1971 WPCF M 30                     | PC # 2 Basin                               |             |                 | 106.00      |            | 45.0 ft  |         |               |                   |               |              |                                   | 3.73     | 33%         |          |             |                    |                                  |
|                                      | 1971 WPCF M 30                     | PC # 2 Influent well                       |             |                 |             | 7 ft       | 18.0 in  |         |               |                   |               |              |                                   | 3.73     | 33%         |          |             |                    |                                  |
|                                      | 1971 WPCF M 30                     | PC # 2 24-In Influent                      |             |                 |             | 18 ft      | 24.0 in  |         |               |                   |               |              |                                   | 3.73     | 33%         |          |             |                    |                                  |
| 1971 WPCF M 30                       | 36-In Influent pipe                |  |             |                 | 32 ft       | 36.0 in    |          |         |               |                   |               |              | 3.73                              | 33%      |             |          |             |                    |                                  |
| PC Flow Split Structure              | 1971 WPCF M 30                     | Drop Box to Primary Clarifier No.2         |             |                 | 108.00      | 40.0 in    |          | 40.0 in |               |                   |               |              |                                   | 3.73     | 33%         |          |             |                    |                                  |
|                                      | 1971 WPCF M 30                     | Primary Clarifier Distribution Box Weir    |             | 120.00          | 117.00      | 4.0 ft     |          |         |               |                   |               |              |                                   | 3.73     | 33%         |          |             |                    | Flow is pumped to this location. |

\*All elevations on the 1929 Datum per 1971 WPCF Drawings

**Drawing Sets Used to Develop Hydraulic Elements List**

| YEAR | DRAWING SET                               | Abbr.     |
|------|---|-----------|
| 2002 | B&C Secondary Clarifier # 5 Expansion     | 2002 SC   |
| 1983 | M&E Plant Expansion                       | 1983 Exp. |
| 1971 | Yoder - Trotter - Orlob & Associates WPCF | 1971 WPCF |

**Input Flows**

| YEAR | CONDITION        | FLOW (MGD) |       |       |
|------|------------------|------------|-------|-------|
|      |                  | INFLUENT   | RAS   | MLR   |
| 2010 | Average          | 4.05       | 3.85  | --    |
|      | Peak Wet Weather | 10.00      | 5.00  | --    |
| 2030 | Maximum Month    | 6.09       | 4.87  | 12.18 |
|      | Maximum Day      | 11.30      | 9.04  | 22.6  |
|      | Peak Wet Weather | 20.00      | 10.00 |       |

**HYDRAULIC ELEMENTS LIST - PWWF**  
Pinole/Hercules WPCP Predesign

| FACILITY                              | DWG. NO.                   | COMPONENT                                  | ELEVATIONS* |                 |             | DIMENSIONS  |          |            |               |                   | LOSSES | FLOW         |             |          |             |          |                                  | EXTENDED DESCRIPTION  |
|---------------------------------------|----------------------------|--|-------------|-----------------|-------------|-------------|----------|------------|---------------|-------------------|--------|--------------|-------------|----------|-------------|----------|----------------------------------|---|
|                                       |                            |  | WSE (ft)    | TOP / ROOF (ft) | INVERT (ft) | LENGTH (ft) | DIAMETER | WIDTH (ft) | SLOPE (ft/ft) | DEPTH (ft)        |        | PWWF Flow    |             |          |             |          |                                  |   |
|                                       |                            |  |             |                 |             |             |          |            |               |                   |        | FORWARD FLOW | PERCENT (%) | RAS FLOW | PERCENT (%) | MLS FLOW | PERCENT (%)                      |   |
| Chlorine Contact Basin                | 2002 SC G-4                | Effluent Weir                              | 107.54      |                 | 107.15      | 4.50        |          |            |               |                   |        | 10.00        | 50%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M-54             | Basin                                      | 107.55      | 110.50          | 103.25      | 140.0 ft    |          | 4.0 ft     |               |                   |        | 10.00        | 50%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M-54             | Slide Gate                                 | 107.82      |                 | 103.25      |             |          | 24.0 in    |               |                   |        | 10.00        | 50%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M-54             | Influent Box                               | 107.82      |                 | 103.25      | 8.0 ft      |          | 4.0 ft     |               |                   |        | 20.00        | 100%        |          |             |          |                                  |   |
|                                       | Figure C                   | 42 - IN SCE                                | 108.20      |                 |             | 116.0 ft    | 42.0 in  |            |               |                   |        | 20.00        | 100%        |          |             |          |                                  |   |
| Figure C                              | SC #1 Effluent Connection  | 108.48                                     |             |                 |             |             | 30.0 in  |            |               |                   |        |              |             |          |             |          |                                  |   |
| Secondary Clarifier # 1               | Not yet produced           | SC # 1 36" Effluent Pipe                   | 108.77      |                 |             | 70 ft       | 30.0 in  |            |               |                   |        | 6.00         | 30%         |          |             |          |                                  | 30% to each new SC (1,2), 14% to each old SC (3,4,5) Assumptions made for design of a 65' Ø central feed / peripheral take off clarifier, with v notch weir.90 deg V-Notches, spaced 4.5" O.C. = 594. 63' diameter No drawings produced yet |
|                                       |                            | SC # 1 Effluent Box                        | 108.77      |                 | 90          | 4 ft        |          | 4 ft       |               |                   |        | 6.00         | 30%         |          |             |          |                                  |   |
|                                       |                            | SC # 1 Effluent Launder                    | 109.25      |                 | 107         | 100 ft      |          | 1.0 ft     | 0.004         |                   |        | 3.00         | 15%         | 1.50     | 15%         |          |                                  |   |
|                                       | Weir Elev. Increased by 4" | SC # 1 Effluent Weir                       |             |                 | 109.3       | 204 ft      |          |            |               |                   |        | 6.00         | 30%         |          |             |          |                                  |   |
|                                       |                            | SC #1                                      | 109.30      | 112.00          | 90.00       |             | 65.0 ft  |            | 0.00522222    | 22.5 ft -22.03 ft |        | 6.00         | 30%         | 3.00     | 30%         |          |                                  |   |
|                                       |                            | SC # 1 Inlet Ports                         | 109.47      | 109.8 ft        | 106.00 ft   |             |          | 0.5 ft     |               | 2.5 ft            |        | 6.00         | 30%         | 3.00     | 30%         |          |                                  |   |
| Secondary Clarifier Distribution Box  | See TM                     | SC #2 Influent Box                         |             | 113.50          | 100.00      | 3.0 ft      |          | 7.5        |               | 13.5 ft           |        | 6.00         | 30%         | 3.00     | 30%         |          | New splitter box required,       |   |
|                                       | See TM                     | Submerged Weir SC 5 Dist. Box Weir         |             |                 | 110.00      | 7.0 ft      |          |            |               |                   | 6.00   | 30%          | 3.00        | 30%      |             |          |                                  |   |
|                                       | See TM                     | SC Distribution Box                        |             | 113.50          | 100.00      | 9.0 ft      |          | 30.0 ft    |               | 13.50 ft          |        | 20.00        | 100%        | 10.00    | 100%        |          |                                  |   |
| AB # 3,4 Zone E Contact Stabilization | Not yet produced           | AB No. 3 36-IN Effluent                    |             |                 |             | 5.0 ft      | 36.0 in  |            |               |                   |        | 10.00        | 50%         | 5.00     | 50%         |          |                                  |   |
|                                       | Not yet produced           | AB No. 3 36-IN Gate                        |             |                 | 105.50      |             | 36.0 in  |            |               |                   |        |              |             |          |             |          |                                  |   |
|                                       | 1983 Exp. S-4              | AB No. 3 ML Drop Box                       | 112.49      | 113.5 ft        | 105.5 ft    | 3.0 ft      |          | 3.0 ft     |               | 16.0 ft           |        | 10.00        | 50%         | 5.00     | 50%         |          |                                  |   |
|                                       | 1983 Exp. S-4              | ML Effluent Channel                        | 112.50      | 113.5 ft        | 109.25 ft   | 5.5 ft      |          | 3.0 ft     |               | 4.0 ft            |        | 10.00        | 50%         | 5.00     | 50%         |          | High headloss                    |   |
|                                       | 1983 Exp. M-7              | AB No. 3 - Effluent Sluice Gate            | 112.88      | 113.5 ft        | 109.25 ft   | --          |          | 36.0 in    |               | 30.0 in           |        | 10.00        | 50%         | 5.00     | 50%         |          | Oriface DS control               |   |
| Figure 10                             | AB No. 3 Zone E            | 112.89                                     | 113.5 ft    | 96.5 ft         | 95.0 ft     |             | 20.0 ft  |            | 17.0 ft       |                   | 10.00  | 50%          | 5.00        | 50%      |             |          |                                  |   |
| PWWF Contact Stabilization            | 1983 Exp. S-4              | AB No. 3 Step Feed Discharge Gates         | 112.92      | 113.50          | 110.50      |             |          | 2.0 ft     |               | 3.0 ft            |        | 10.00        | 50%         |          |             |          |                                  |   |
|                                       | 1983 Exp S-4               | AB No. 3 Step Feed Channel                 | 112.96      | 113.5 ft        | 110.0 ft    | 108.0 ft    |          | 3.0 ft     |               |                   |        | 10.00        | 50%         |          |             |          | High headloss                    |   |
|                                       | 1984 Exp S-4               | AB No. 3 Step Feed Channel                 | 112.98      |                 | 110.0 ft    | 8.0 ft      |          | 3.0 ft     |               |                   |        |              |             |          |             |          |                                  |   |
|                                       | 1983 Exp.                  | 42-IN RCP Influent Pipe AB No. 3/4         | 113.10      |                 |             | 58.0 ft     | 42.0 in  |            |               |                   |        | 10.00        | 50%         |          |             |          |                                  |   |
|                                       | 1983 Exp.                  | 42-IN RCP Tee Line to Branch               | 113.20      |                 |             |             | 42.0 in  |            |               |                   |        | 10.00        | 50%         |          |             |          |                                  |   |
| AB # 3,4 Contact Stabilization        | Figure 10                  | Baffle Zone E to D                         |             |                 | 96.5 ft     | --          |          | 24.0 in    |               | 24.0 in           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | Figure 10                  | AB No. 3 Zone 1D                           | 112.91      | 113.5 ft        | 109.0 ft    | 95.0 ft     |          | 20.0 ft    |               | 17.0 ft           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | Figure 10                  | Baffle Zone D to C                         |             |                 | 96.5 ft     | --          |          | 24.0 in    |               | 24.0 in           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | Figure 10                  | AB No. 4 Zone 1C                           | 112.93      | 113.5 ft        | 109.0 ft    | 130.0 ft    |          | 20.0 ft    |               | 17.0 ft           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | Figure 10                  | Baffle Zone C to B                         |             |                 | 96.5 ft     | --          |          | 24.0 in    |               | 24.0 in           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | Figure 10                  | AB No 4. Zone 1B                           | 112.95      | 113.5 ft        | 109.0 ft    | 30.0 ft     |          | 20.0 in    |               | 17.0 in           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | Figure 10                  | Baffle Zone B to A                         |             |                 | 96.5 ft     | --          |          | 24.0 in    |               | 24.0 in           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | 1983 Exp. S-4              | AB No. 4 Zone 1A                           | 112.97      | 113.5 ft        | 96.5 ft     | 30.0 ft     |          | 20.0 ft    |               | 17.0 ft           |        | 0.00         | 0%          | 5.00     | 50%         |          |                                  |   |
|                                       | 1983 Exp. M-7              | AB No. 4 - Influent Sluice Gate            |             | 113.5 ft        | 109.25 ft   | --          |          | 36.0 in    |               | 30.0 in           |        | 0.00         | 0%          | 5.00     | 50%         |          | Oriface DS control               |   |
| 1983 Exp. S-4                         | AB No. 4 Influent Channel  | 113.00                                     | 113.5 ft    | 109.25 ft       | 18.0 ft     |             | 3.0 ft   |            | 4.0 ft        |                   | 0.00   | 0%           | 5.00        | 50%      |             |          |                                  |   |
| 1983 Exp. S-4                         | AB No. 4 Sloped Channel    |  | 113.5 ft    | 109.25 ft       | 5.3 ft      |             | 3.0 ft   | 0.141 ft   |               |                   | 0.00   | 0%           | 5.00        | 50%      |             |          |                                  |   |
| Primary Effluent Junction Box         | 1971 EXP M 30.2            | 42-IN RCP PC Effluent Pipe to Junction Box | 114.05      |                 |             | 224 ft      | 45.0 in  |            |               |                   |        | 20.00        | 100%        |          |             |          |                                  |   |
|                                       | 1971 EXP M 30.2            | PE Junction Box                            | 114.05      | 114.5 ft        | 104.5 ft    | 16.5 ft     |          | 7.0 ft     |               | 10.0 ft           |        | 20.00        | 100%        |          |             |          |                                  |   |
| Primary Clarifier #2                  | 1983 - S.2                 | PC # 2 24 -IN RCP Effluent                 | 114.19      |                 |             | 120         |          |            |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M 30             | PC # 2 Effluent Box                        | 114.19      | 116.00          | 112.00      | 4           |          | 1.5 ft     |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M 30             | PC # 2 Effluent Trough/Launder             | 114.25      |                 | 112.00      | 78          |          | 1.0 ft     | -0.0094       |                   |        | 1.98         | 17%         |          |             |          |                                  |   |
|                                       | 2002 SC G4                 | PC # 2 Effluent Weir                       | 114.22      |                 | 114.25      | 135         |          |            |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M 30             | PC # 2 Basin                               | 114.42      |                 | 106.00      |             | 45.0 ft  |            |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M 30             | PC # 2 18-IN Influent wel                  | 114.42      |                 |             | 7 ft        | 18.0 in  |            |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M 30             | PC # 2 24-IN Influent                      | 114.72      |                 |             | 18 ft       | 24.0 in  |            |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M 30             | 36-In Influent pipe                        | 114.79      |                 |             | 32 ft       | 36.0 in  |            |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
| PC Flow Split Structure               | 1971 WPCF M 30             | Drop Box to Primary Clarifier No.2         | 114.87      |                 |             | 40.0 in     |          | 40.0 in    |               |                   |        | 3.96         | 33%         |          |             |          |                                  |   |
|                                       | 1971 WPCF M 30             | Primary Clarifier Distribution Box Weir    | 117.66      | 120.00          | 117.00      | 4.0 ft      |          |            |               |                   |        | 3.96         | 33%         |          |             |          | Flow is pumped to this location. |   |

\*All elevations on the 1929 Datum per 1971 WPCF Drawings

**Drawing Sets Used to Develop Hydraulic Elements List**

| YEAR | DRAWING SET                               | Abbr.     |
|------|---|-----------|
| 2002 | B&C Secondary Clarifier # 5 Expansion     | 2002 SC   |
| 1983 | M&E Plant Expansion                       | 1983 Exp. |
| 1971 | Yoder - Trotter - Orlob & Associates WPCF | 1971 WPCF |

**Input Flows**

| YEAR | CONDITION        | FLOW (MGD) |       |        |
|------|------------------|------------|-------|--------|
|      |                  | INFLUENT   | RAS   | MLR    |
| 2010 | Average          | 4.05       | 3.85  | 5.8725 |
|      | Peak Wet Weather | 10.00      | 5.00  | --     |
| 2030 | Maximum Month    | 6.09       | 5.79  | 8.8305 |
|      | Maximum Day      | 11.30      | 10.74 | 16.385 |
|      | Peak Wet Weather | 20.00      | 10.00 | 0.00   |

Appendix B. Pinole/Hercules WPCP VH Output

DRAFT

# Pinole ADWF Flow.vhf

## Hydraulic Profile

### Current flow conditions

| Forward Flow | Return I Flow | Return II Flow | Return III Flow |
|--------------|---------------|----------------|-----------------|
| 4.06 mgd     | 3.25 mgd      | 8.12 mgd       | -----           |

### Section Description

### Water Surface Elevation

**Starting water surface elevation**

**107**

#### **Effluent Weir**

**107.71**

Weir invert (top of weir) = 107.15

Weir length = 4.5 ft

Weir 'C' coefficient = 3.33

Flow over weir = 4.06 mgd

Weir submergence = unsubmerged

Head over weir = 0.56 ft

#### **Chlorine Contact Basin**

**107.72**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 140 ft

Channel width/diameter = 4 ft

Flow = 2.03 mgd

Downstream channel invert = 103.25

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 17.84 ft<sup>2</sup>

Hydraulic radius = 1.381

Normal depth = infinite

Critical depth = 0.27 ft

Depth downstream = 4.46 ft

Bend loss = 0 ft

Depth upstream = 4.47 ft

Velocity = 0.18 ft/s

Flow profile = Horizontal

#### **Slide Gate**

**107.73**

Opening type = rectangular gate

Opening diameter/width = 24 in

Gate height = 36 in

Invert = 103.25

Number of gates = 1

Flow through gate(s) = 2.03 mgd

## Section Description

## Water Surface Elevation

Total area of opening(s) = 6 ft<sup>2</sup>  
Velocity through gate(s) = 0.52 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.01 ft  
Downstream water level = 107.72  
Upstream water level = 107.73

### **CC Basin Influent Box**

**107.73**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 8 ft  
Channel width/diameter = 4 ft  
Flow = 4.06 mgd  
Downstream channel invert = 103.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 17.91 ft<sup>2</sup>  
Hydraulic radius = 1.382  
Normal depth = infinite  
Critical depth = 0.43 ft  
Depth downstream = 4.48 ft  
Bend loss = 0 ft  
Depth upstream = 4.48 ft  
Velocity = 0.35 ft/s  
Flow profile = Horizontal

### **42-IN SC Effluent**

**107.75**

Pipe shape = Circular  
Diameter = 42 in  
Length = 116 ft  
Flow = 4.06 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.75  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 0.65 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.01 ft  
Total loss = 0.02 ft

### **SC #2 Effluent Connection**

**107.75**

Tee type = branch to line  
Diameter of pipe line = 42 in  
Diameter of pipe branch = 30 in

**Section Description****Water Surface Elevation**

Flow through tee = 1.22 mgd  
Velocity through tee = 0.38 ft/s  
Total tee K value = 1.69  
Overall head loss = 0 ft

**SC #2 - 30-IN Effluent****107.76**

Pipe shape = Circular  
Diameter = 30 in  
Length = 70 ft  
Flow = 1.22 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1  
Pipe area = 4.91 ft<sup>2</sup>  
Pipe hydraulic radius = 0.625  
Age factor = 1  
Solids factor = 1  
Velocity = 0.38 ft/s  
Friction loss = 0 ft  
Fitting loss = 0 ft  
Total loss = 0 ft

**SC #2 Effluent Box****107.76**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 4 ft  
Channel width/diameter = 4 ft  
Flow = 1.22 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 71.04 ft<sup>2</sup>  
Hydraulic radius = 1.798  
Normal depth = infinite  
Critical depth = 0.19 ft  
Depth downstream = 17.76 ft  
Bend loss = 0 ft  
Depth upstream = 17.76 ft  
Velocity = 0.03 ft/s  
Flow profile = Horizontal

**SC #2 Effluent Launder****107.85**

Launder invert = 107  
Launder length = 100 ft  
Launder width = 1 ft  
Launder slope = 0.004 ft/ft  
Flow through launder = 0.61 mgd

**Section Description****Water Surface Elevation**

Critical depth = 0.3 ft  
Downstream depth = 0.76 ft  
Upstream depth = 0.45 ft

**SC #2 Effluent Weir****109.37**

Invert of V notch = 109.3  
Angle of V notch = 90 degrees  
Number of notches = 594  
Total flow over weir = 1.22 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.07 ft

**SC #2****109.37**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 75 ft  
Channel width/diameter = 75 ft  
Flow = 2.2 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 1452.75 ft<sup>2</sup>  
Hydraulic radius = 12.773  
Normal depth = infinite  
Critical depth = 0.04 ft  
Depth downstream = 19.37 ft  
Bend loss = 0 ft  
Depth upstream = 19.37 ft  
Velocity = 0 ft/s  
Flow profile = Horizontal

**SC #2 Inlet Ports****109.38**

Opening type = rectangular orifice  
Opening diameter/width = 6 in  
Opening height = 30 in  
Invert = 106  
Number of openings = 6  
Flow through opening(s) = 2.421 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through opening(s) = 0.5 ft/s  
Flow behavior = orifice, downstream control  
Orifice loss = 0.01 ft  
Downstream water level = 109.37  
Upstream water level = 109.38

**SC #2 - 36-IN Influent****109.39**

Pipe shape = Circular  
Diameter = 36 in

## Section Description

## Water Surface Elevation

Length = 200 ft  
Flow = 2.2 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 2  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 0.48 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.01 ft  
Total loss = 0.01 ft

### **SC #2 Influent Box**

**109.39**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3 ft  
Channel width/diameter = 7.5 ft  
Flow = 2.2 mgd  
Downstream channel invert = 100  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 70.43 ft<sup>2</sup>  
Hydraulic radius = 2.68  
Normal depth = infinite  
Critical depth = 0.19 ft  
Depth downstream = 9.39 ft  
Bend loss = 0 ft  
Depth upstream = 9.39 ft  
Velocity = 0.05 ft/s  
Flow profile = Horizontal

### **SC Dist Box Weir #2**

**110.28**

Weir invert (top of weir) = 110  
Weir length = 7 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 2.2 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.28 ft

### **SC Distribution Box**

**110.28**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 9 ft  
Channel width/diameter = 30 ft  
Flow = 7.31 mgd

## Section Description

## Water Surface Elevation

Downstream channel invert = 105.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 143.33 ft<sup>2</sup>  
Hydraulic radius = 3.623  
Normal depth = infinite  
Critical depth = 0.16 ft  
Depth downstream = 4.78 ft  
Bend loss = 0 ft  
Depth upstream = 4.78 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **AB 36-IN Effluent**

**110.35**

Pipe shape = Circular  
Diameter = 36 in  
Length = 5 ft  
Flow = 7.31 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.76  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 1.6 ft/s  
Friction loss = 0 ft  
Fitting loss = 0.07 ft  
Total loss = 0.07 ft

### **AB Exit Gate**

**110.46**

Opening type = circular gate  
Opening diameter/width = 36 in  
Gate height = 36 in  
Invert = 105.5  
Number of gates = 1  
Flow through gate(s) = 7.31 mgd  
Total area of opening(s) = 7.07 ft<sup>2</sup>  
Velocity through gate(s) = 1.6 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.11 ft  
Downstream water level = 110.35  
Upstream water level = 110.46

### **AB 3 ML Drop Box**

**110.46**

Channel shape = Rectangular  
Manning's 'n' = 0.012

## Section Description

## Water Surface Elevation

Channel length = 3 ft  
Channel width/diameter = 3 ft  
Flow = 7.31 mgd  
Downstream channel invert = 105.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 14.88 ft<sup>2</sup>  
Hydraulic radius = 1.152  
Normal depth = infinite  
Critical depth = 0.76 ft  
Depth downstream = 4.96 ft  
Bend loss = 0 ft  
Depth upstream = 4.96 ft  
Velocity = 0.76 ft/s  
Flow profile = Horizontal

### **AB 3 ML Effluent Channel**

**110.47**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 5.5 ft  
Channel width/diameter = 3 ft  
Flow = 7.31 mgd  
Downstream channel invert = 109.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 3.65 ft<sup>2</sup>  
Hydraulic radius = 0.672  
Normal depth = infinite  
Critical depth = 0.76 ft  
Depth downstream = 1.21 ft  
Bend loss = 0 ft  
Depth upstream = 1.22 ft  
Velocity = 3.11 ft/s  
Flow profile = Horizontal

### **AB 3 Effluent Sluice Gate**

**110.56**

Opening type = rectangular gate  
Opening diameter/width = 36 in  
Gate height = 30 in  
Invert = 109.25  
Number of gates = 1  
Flow through gate(s) = 7.31 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through gate(s) = 1.51 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.09 ft  
Downstream water level = 110.47

## Section Description

## Water Surface Elevation

Upstream water level = 110.56

### **AB 3 Zone E**

**110.57**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 15.43 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 281.27 ft<sup>2</sup>  
Hydraulic radius = 5.844  
Normal depth = infinite  
Critical depth = 0.35 ft  
Depth downstream = 14.06 ft  
Bend loss = 0 ft  
Depth upstream = 14.07 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **Baffle Wall E to D**

**110.6**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 15.43 mgd  
Weir submergence = fully submerged  
Head over weir = 1.6 ft

### **Contact Stabilization Influent Pipe**

**110.63**

Pipe shape = Circular  
Diameter = 24 in  
Length = 100 ft  
Flow = 4.06 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 0  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 1  
Solids factor = 1  
Velocity = 2 ft/s  
Friction loss = 0.07 ft  
Fitting loss = 0 ft  
Total loss = 0.07 ft

### **AB 3 Zone D**

**110.6**

## Section Description

## Water Surface Elevation

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 15.43 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 281.91 ft<sup>2</sup>  
Hydraulic radius = 5.85  
Normal depth = infinite  
Critical depth = 0.35 ft  
Depth downstream = 14.1 ft  
Bend loss = 0 ft  
Depth upstream = 14.1 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **Baffle Wall D to C**

**110.63**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 15.43 mgd  
Weir submergence = fully submerged  
Head over weir = 1.63 ft

### **AB 4 Zone C**

**110.63**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 130 ft  
Channel width/diameter = 20 ft  
Flow = 15.43 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 282.55 ft<sup>2</sup>  
Hydraulic radius = 5.855  
Normal depth = infinite  
Critical depth = 0.35 ft  
Depth downstream = 14.13 ft  
Bend loss = 0 ft  
Depth upstream = 14.13 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **Baffle Wall C to B**

**110.66**

Weir invert (top of weir) = 109

## Section Description

## Water Surface Elevation

Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 15.43 mgd  
Weir submergence = fully submerged  
Head over weir = 1.66 ft

### **AB Zone B**

**110.66**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 30 ft  
Channel width/diameter = 20 ft  
Flow = 15.43 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 283.19 ft<sup>2</sup>  
Hydraulic radius = 5.861  
Normal depth = infinite  
Critical depth = 0.35 ft  
Depth downstream = 14.16 ft  
Bend loss = 0 ft  
Depth upstream = 14.16 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **Baffle Wall B to A**

**110.69**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 15.43 mgd  
Weir submergence = fully submerged  
Head over weir = 1.69 ft

### **AB Zone A**

**110.69**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 30 ft  
Channel width/diameter = 20 ft  
Flow = 15.43 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 283.83 ft<sup>2</sup>  
Hydraulic radius = 5.866  
Normal depth = infinite  
Critical depth = 0.35 ft  
Depth downstream = 14.19 ft  
Bend loss = 0 ft

## Section Description

## Water Surface Elevation

Depth upstream = 14.19 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **AB 4 Influent Sluice Gate**

**110.72**

Opening type = rectangular gate  
Opening diameter/width = 36 in  
Gate height = 30 in  
Invert = 110  
Number of gates = 2  
Flow through gate(s) = 7.31 mgd  
Total area of opening(s) = 15 ft<sup>2</sup>  
Velocity through gate(s) = 0.75 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.02 ft  
Downstream water level = 110.69  
Upstream water level = 110.72

### **AB 4 Influent Channel**

**110.72**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3 ft  
Channel width/diameter = 3 ft  
Flow = 7.31 mgd  
Downstream channel invert = 109.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 4.4 ft<sup>2</sup>  
Hydraulic radius = 0.742  
Normal depth = infinite  
Critical depth = 0.76 ft  
Depth downstream = 1.47 ft  
Bend loss = 0 ft  
Depth upstream = 1.47 ft  
Velocity = 2.57 ft/s  
Flow profile = Horizontal

### **AB 4 Influent Slopped Channel**

**110.71**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 5.3 ft  
Channel width/diameter = 3 ft  
Flow = 7.31 mgd  
Downstream channel invert = 109.25  
Channel slope = 0.0141 ft/ft  
Channel side slope = not applicable  
Area of flow = 4.28 ft<sup>2</sup>  
Hydraulic radius = 0.732

## Section Description

## Water Surface Elevation

Normal depth = 0.5 ft  
Critical depth = 0.76 ft  
Depth downstream = 1.47 ft  
Bend loss = 0 ft  
Depth upstream = 1.39 ft  
Velocity = 2.56 ft/s  
Flow profile = Steep

### **AB 4 Influent Split Box-Channel**

**110.83**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 12.7 ft  
Channel width/diameter = 4.5 ft  
Flow = 7.31 mgd  
Downstream channel invert = 110  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 3.29 ft<sup>2</sup>  
Hydraulic radius = 0.552  
Normal depth = infinite  
Critical depth = 0.58 ft  
Depth downstream = 0.71 ft  
Bend loss = 0.08 ft  
Depth upstream = 0.83 ft  
Velocity = 3.54 ft/s  
Flow profile = Horizontal

### **AB 3/4 42-IN Influent Pipe**

**110.87**

Pipe shape = Circular  
Diameter = 42 in  
Length = 58 ft  
Flow = 7.31 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.5  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 1.18 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.03 ft  
Total loss = 0.04 ft

### **42-IN Tee to AB 3/4**

**110.88**

Tee type = run of tee  
Diameter of pipe run past tee = 42 in

**Section Description**

**Water Surface Elevation**

Flow through tee = 7.31 mgd  
Velocity through tee = 1.18 ft/s  
Total tee K value = 0.6  
Overall head loss = 0.01 ft

**42-IN PC Effluent to PC Junction Box**

**111.03**

Pipe shape = Circular  
Diameter = 42 in  
Length = 244 ft  
Flow = 7.31 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 2  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 2.348  
Solids factor = 1  
Velocity = 1.18 ft/s  
Friction loss = 0.11 ft  
Fitting loss = 0.04 ft  
Total loss = 0.15 ft

**Prim. Eff. Junction Box**

**111.03**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 16.5 ft  
Channel width/diameter = 7 ft  
Flow = 7.31 mgd  
Downstream channel invert = 104.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 45.71 ft<sup>2</sup>  
Hydraulic radius = 2.279  
Normal depth = infinite  
Critical depth = 0.43 ft  
Depth downstream = 6.53 ft  
Bend loss = 0 ft  
Depth upstream = 6.53 ft  
Velocity = 0.25 ft/s  
Flow profile = Horizontal

**PC 2 24-IN Effluent**

**111.08**

Pipe shape = Circular  
Diameter = 24 in  
Length = 120 ft  
Flow = 1.353 mgd  
Friction method = Hazen Williams

## Section Description

## Water Surface Elevation

Friction factor = 100  
Total fitting K value = 2.4  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 0.67 ft/s  
Friction loss = 0.04 ft  
Fitting loss = 0.02 ft  
Total loss = 0.05 ft

### **PC 2 Effluent Box**

**111.08**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 1.5 ft  
Channel width/diameter = 4 ft  
Flow = 1.353 mgd  
Downstream channel invert = 106  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 20.32 ft<sup>2</sup>  
Hydraulic radius = 1.435  
Normal depth = infinite  
Critical depth = 0.2 ft  
Depth downstream = 5.08 ft  
Bend loss = 0 ft  
Depth upstream = 5.08 ft  
Velocity = 0.1 ft/s  
Flow profile = Horizontal

### **PC 2 Effluent Launder**

**112.64**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 78 ft  
Channel width/diameter = 1 ft  
Flow = 0.677 mgd  
Downstream channel invert = 112  
Channel slope = 0.0015 ft/ft  
Channel side slope = not applicable  
Area of flow = 0.43 ft<sup>2</sup>  
Hydraulic radius = 0.23  
Normal depth = 0.54 ft  
Critical depth = 0.32 ft  
Depth downstream = 0.32 ft  
Bend loss = 0 ft  
Depth upstream = 0.53 ft  
Velocity = 3.23 ft/s

**Section Description****Water Surface Elevation**

Flow profile = Mild

**PC 2 Effluent Weir****114.36**

Invert of V notch = 114.25

Angle of V notch = 90 degrees

Number of notches = 212

Total flow over weir = 1.353 mgd

Weir submergence = unsubmerged

Head over weir = 0.11 ft

**PC 2 Basin****114.36**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 45 ft

Channel width/diameter = 45 ft

Flow = 1.353 mgd

Downstream channel invert = 106

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 376.19 ft<sup>2</sup>

Hydraulic radius = 6.095

Normal depth = infinite

Critical depth = 0.04 ft

Depth downstream = 8.36 ft

Bend loss = 0 ft

Depth upstream = 8.36 ft

Velocity = 0.01 ft/s

Flow profile = Horizontal

**PC 2 Influent Well****114.4**

Pipe shape = Circular

Diameter = 18 in

Length = 7 ft

Flow = 1.353 mgd

Friction method = Hazen Williams

Friction factor = 100

Total fitting K value = 1.25

Pipe area = 1.77 ft<sup>2</sup>

Pipe hydraulic radius = 0.375

Age factor = 2.348

Solids factor = 1

Velocity = 1.18 ft/s

Friction loss = 0.01 ft

Fitting loss = 0.03 ft

Total loss = 0.04 ft

**24-IN Influent Pipe****114.41**

Pipe shape = Circular

## Section Description

## Water Surface Elevation

Diameter = 24 in  
Length = 10 ft  
Flow = 1.353 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 0.42  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 0.67 ft/s  
Friction loss = 0 ft  
Fitting loss = 0 ft  
Total loss = 0.01 ft

### **36-IN PC Influent Pipe**

**114.42**

Pipe shape = Circular  
Diameter = 24 in  
Length = 10 ft  
Flow = 1.353 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 0.42  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 0.67 ft/s  
Friction loss = 0 ft  
Fitting loss = 0 ft  
Total loss = 0.01 ft

### **Drop Box to Primary Clarifier No 2**

**114.42**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3.5 ft  
Channel width/diameter = 3.5 ft  
Flow = 1.353 mgd  
Downstream channel invert = 108  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 22.47 ft<sup>2</sup>  
Hydraulic radius = 1.375  
Normal depth = infinite  
Critical depth = 0.22 ft  
Depth downstream = 6.42 ft  
Bend loss = 0 ft

**Section Description**

**Water Surface Elevation**

Depth upstream = 6.42 ft  
Velocity = 0.09 ft/s  
Flow profile = Horizontal

**Primary Clarifier Distribution Box Weir**

**117.32**

Weir invert (top of weir) = 117  
Weir length = 3.5 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 1.347 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.32 ft

# Pinole MM-MD Flow.vhf

## Hydraulic Profile

### Current flow conditions

| Forward Flow | Return I Flow | Return II Flow | Return III Flow |
|--------------|---------------|----------------|-----------------|
| 11.3 mgd     | 9.04 mgd      | 22.6 mgd       | -----           |

### Section Description

### Water Surface Elevation

**Starting water surface elevation**

**107**

#### **Effluent Weir**

**107.85**

Weir invert (top of weir) = 107.15

Weir length = 4.5 ft

Weir 'C' coefficient = 3.33

Flow over weir = 5.65 mgd

Weir submergence = unsubmerged

Head over weir = 0.7 ft

#### **Chlorine Contact Basin**

**107.88**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 140 ft

Channel width/diameter = 4 ft

Flow = 5.65 mgd

Downstream channel invert = 103.25

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 18.4 ft<sup>2</sup>

Hydraulic radius = 1.394

Normal depth = infinite

Critical depth = 0.53 ft

Depth downstream = 4.6 ft

Bend loss = 0.03 ft

Depth upstream = 4.63 ft

Velocity = 0.48 ft/s

Flow profile = Horizontal

#### **Slide Gate**

**107.96**

Opening type = rectangular gate

Opening diameter/width = 36 in

Gate height = 24 in

Invert = 103.25

Number of gates = 1

Flow through gate(s) = 5.65 mgd

## Section Description

## Water Surface Elevation

Total area of opening(s) = 6 ft<sup>2</sup>  
Velocity through gate(s) = 1.46 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.09 ft  
Downstream water level = 107.88  
Upstream water level = 107.96

### **CC Basin Influent Box**

**107.96**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 8 ft  
Channel width/diameter = 4 ft  
Flow = 11.3 mgd  
Downstream channel invert = 103.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 18.85 ft<sup>2</sup>  
Hydraulic radius = 1.404  
Normal depth = infinite  
Critical depth = 0.84 ft  
Depth downstream = 4.71 ft  
Bend loss = 0 ft  
Depth upstream = 4.71 ft  
Velocity = 0.93 ft/s  
Flow profile = Horizontal

### **42-IN SC Effluent**

**108.09**

Pipe shape = Circular  
Diameter = 42 in  
Length = 116 ft  
Flow = 11.3 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.75  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 1.82 ft/s  
Friction loss = 0.03 ft  
Fitting loss = 0.09 ft  
Total loss = 0.12 ft

### **SC #2 Effluent Connection**

**108.12**

Tee type = branch to line  
Diameter of pipe line = 42 in  
Diameter of pipe branch = 30 in

**Section Description**

**Water Surface Elevation**

Flow through tee = 3.39 mgd  
Velocity through tee = 1.07 ft/s  
Total tee K value = 1.69  
Overall head loss = 0.03 ft

**SC #2 - 36-IN Effluent** **108.13**

Pipe shape = Circular  
Diameter = 36 in  
Length = 70 ft  
Flow = 3.39 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 0.74 ft/s  
Friction loss = 0 ft  
Fitting loss = 0.01 ft  
Total loss = 0.01 ft

**SC #2 Effluent Box** **108.13**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 4 ft  
Channel width/diameter = 4 ft  
Flow = 3.748 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 72.52 ft<sup>2</sup>  
Hydraulic radius = 1.801  
Normal depth = infinite  
Critical depth = 0.4 ft  
Depth downstream = 18.13 ft  
Bend loss = 0 ft  
Depth upstream = 18.13 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

**SC #2 Effluent Launder** **108.45**

Launder invert = 107  
Launder length = 100 ft  
Launder width = 1 ft  
Launder slope = 0.004 ft/ft  
Flow through launder = 1.7 mgd

**Section Description****Water Surface Elevation**

Critical depth = 0.6 ft  
Downstream depth = 1.13 ft  
Upstream depth = 1.05 ft

**SC #2 Effluent Weir****109.41**

Invert of V notch = 109.3  
Angle of V notch = 90 degrees  
Number of notches = 594  
Total flow over weir = 3.748 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.11 ft

**SC #2****109.41**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 75 ft  
Channel width/diameter = 75 ft  
Flow = 6.1 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 1455.7 ft<sup>2</sup>  
Hydraulic radius = 12.79  
Normal depth = infinite  
Critical depth = 0.08 ft  
Depth downstream = 19.41 ft  
Bend loss = 0 ft  
Depth upstream = 19.41 ft  
Velocity = 0.01 ft/s  
Flow profile = Horizontal

**SC #2 Inlet Ports****109.48**

Opening type = rectangular orifice  
Opening diameter/width = 6 in  
Opening height = 30 in  
Invert = 106  
Number of openings = 6  
Flow through opening(s) = 6.2 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through opening(s) = 1.28 ft/s  
Flow behavior = orifice, downstream control  
Orifice loss = 0.07 ft  
Downstream water level = 109.41  
Upstream water level = 109.48

**SC #2 - 36-IN Influent****109.57**

Pipe shape = Circular  
Diameter = 36 in

## Section Description

## Water Surface Elevation

Length = 200 ft  
Flow = 6.1 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 2  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 1.34 ft/s  
Friction loss = 0.04 ft  
Fitting loss = 0.06 ft  
Total loss = 0.1 ft

### **SC #2 Influent Box**

**109.57**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3 ft  
Channel width/diameter = 7 ft  
Flow = 6.1 mgd  
Downstream channel invert = 100  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 66.99 ft<sup>2</sup>  
Hydraulic radius = 2.563  
Normal depth = infinite  
Critical depth = 0.38 ft  
Depth downstream = 9.57 ft  
Bend loss = 0 ft  
Depth upstream = 9.57 ft  
Velocity = 0.14 ft/s  
Flow profile = Horizontal

### **SC Dist Box Weir #5**

**110.57**

Weir invert (top of weir) = 110  
Weir length = 7 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 6.458 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.57 ft

### **SC Distribution Box**

**110.57**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 9 ft  
Channel width/diameter = 35 ft  
Flow = 20.34 mgd

## Section Description

## Water Surface Elevation

Downstream channel invert = 105.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 177.41 ft<sup>2</sup>  
Hydraulic radius = 3.93  
Normal depth = infinite  
Critical depth = 0.29 ft  
Depth downstream = 5.07 ft  
Bend loss = 0 ft  
Depth upstream = 5.07 ft  
Velocity = 0.18 ft/s  
Flow profile = Horizontal

### **AB 36-IN Effluent**

**110.71**

Pipe shape = Circular  
Diameter = 36 in  
Length = 5 ft  
Flow = 10.17 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.76  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 2.23 ft/s  
Friction loss = 0 ft  
Fitting loss = 0.14 ft  
Total loss = 0.14 ft

### **Effluent Gate**

**110.92**

Opening type = circular gate  
Opening diameter/width = 36 in  
Gate height = 36 in  
Invert = 106  
Number of gates = 1  
Flow through gate(s) = 10.179 mgd  
Total area of opening(s) = 7.07 ft<sup>2</sup>  
Velocity through gate(s) = 2.23 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.21 ft  
Downstream water level = 110.71  
Upstream water level = 110.92

### **AB 3 ML Drop Box**

**110.93**

Channel shape = Rectangular  
Manning's 'n' = 0.012

## Section Description

## Water Surface Elevation

Channel length = 3 ft  
Channel width/diameter = 3 ft  
Flow = 10.179 mgd  
Downstream channel invert = 105.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 16.27 ft<sup>2</sup>  
Hydraulic radius = 1.175  
Normal depth = infinite  
Critical depth = 0.95 ft  
Depth downstream = 5.42 ft  
Bend loss = 0 ft  
Depth upstream = 5.43 ft  
Velocity = 0.97 ft/s  
Flow profile = Horizontal

### **AB 3 ML Effluent Channel**

**110.93**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 5.5 ft  
Channel width/diameter = 3 ft  
Flow = 10.179 mgd  
Downstream channel invert = 109.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 5.04 ft<sup>2</sup>  
Hydraulic radius = 0.792  
Normal depth = infinite  
Critical depth = 0.95 ft  
Depth downstream = 1.68 ft  
Bend loss = 0 ft  
Depth upstream = 1.68 ft  
Velocity = 3.13 ft/s  
Flow profile = Horizontal

### **AB 3 Effluent Sluice Gate**

**111.11**

Opening type = rectangular gate  
Opening diameter/width = 36 in  
Gate height = 30 in  
Invert = 109.25  
Number of gates = 1  
Flow through gate(s) = 10.179 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through gate(s) = 2.1 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.18 ft  
Downstream water level = 110.93

## Section Description

## Water Surface Elevation

Upstream water level = 111.11

### **AB 3 Zone E**

**111.11**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 21.479 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 292.23 ft<sup>2</sup>  
Hydraulic radius = 5.937  
Normal depth = infinite  
Critical depth = 0.44 ft  
Depth downstream = 14.61 ft  
Bend loss = 0 ft  
Depth upstream = 14.61 ft  
Velocity = 0.11 ft/s  
Flow profile = Horizontal

### **Baffle Wall E to D**

**111.14**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 21.479 mgd  
Weir submergence = fully submerged  
Head over weir = 2.14 ft

### **Contact Stabilization Influent Pipe**

**111.57**

Pipe shape = Circular  
Diameter = 24 in  
Length = 100 ft  
Flow = 11.3 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 0  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 1  
Solids factor = 1  
Velocity = 5.56 ft/s  
Friction loss = 0.46 ft  
Fitting loss = 0 ft  
Total loss = 0.46 ft

### **AB 3 Zone D**

**111.15**

## Section Description

## Water Surface Elevation

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 21.479 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 292.87 ft<sup>2</sup>  
Hydraulic radius = 5.942  
Normal depth = infinite  
Critical depth = 0.44 ft  
Depth downstream = 14.64 ft  
Bend loss = 0 ft  
Depth upstream = 14.65 ft  
Velocity = 0.11 ft/s  
Flow profile = Horizontal

### **Baffle Wall D to C**

**111.18**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 21.479 mgd  
Weir submergence = fully submerged  
Head over weir = 2.18 ft

### **AB 4 Zone C**

**111.18**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 130 ft  
Channel width/diameter = 20 ft  
Flow = 21.479 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 293.51 ft<sup>2</sup>  
Hydraulic radius = 5.947  
Normal depth = infinite  
Critical depth = 0.44 ft  
Depth downstream = 14.68 ft  
Bend loss = 0 ft  
Depth upstream = 14.68 ft  
Velocity = 0.11 ft/s  
Flow profile = Horizontal

### **Baffle Wall C to B**

**111.21**

Weir invert (top of weir) = 109

## **Section Description**

## **Water Surface Elevation**

Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 21.479 mgd  
Weir submergence = fully submerged  
Head over weir = 2.21 ft

### **AB Zone B**

**111.21**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 30 ft  
Channel width/diameter = 20 ft  
Flow = 21.479 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 294.15 ft<sup>2</sup>  
Hydraulic radius = 5.953  
Normal depth = infinite  
Critical depth = 0.44 ft  
Depth downstream = 14.71 ft  
Bend loss = 0 ft  
Depth upstream = 14.71 ft  
Velocity = 0.11 ft/s  
Flow profile = Horizontal

### **Baffle Wall B to A**

**111.24**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 21.479 mgd  
Weir submergence = fully submerged  
Head over weir = 2.24 ft

### **AB Zone A**

**111.24**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 30 ft  
Channel width/diameter = 20 ft  
Flow = 21.479 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 294.79 ft<sup>2</sup>  
Hydraulic radius = 5.958  
Normal depth = infinite  
Critical depth = 0.44 ft  
Depth downstream = 14.74 ft  
Bend loss = 0 ft

## Section Description

## Water Surface Elevation

Depth upstream = 14.74 ft  
Velocity = 0.11 ft/s  
Flow profile = Horizontal

### **AB 4 Influent Sluice Gate**

**111.29**

Opening type = rectangular gate  
Opening diameter/width = 36 in  
Gate height = 30 in  
Invert = 110  
Number of gates = 2  
Flow through gate(s) = 10.179 mgd  
Total area of opening(s) = 15 ft<sup>2</sup>  
Velocity through gate(s) = 1.05 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.04 ft  
Downstream water level = 111.24  
Upstream water level = 111.29

### **AB 4 Influent Channel**

**111.29**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 4 ft  
Channel width/diameter = 3 ft  
Flow = 10.179 mgd  
Downstream channel invert = 109.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 6.11 ft<sup>2</sup>  
Hydraulic radius = 0.864  
Normal depth = infinite  
Critical depth = 0.95 ft  
Depth downstream = 2.04 ft  
Bend loss = 0 ft  
Depth upstream = 2.04 ft  
Velocity = 2.58 ft/s  
Flow profile = Horizontal

### **AB 4 Influent Sloped Channel**

**111.28**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 5.3 ft  
Channel width/diameter = 3 ft  
Flow = 10.179 mgd  
Downstream channel invert = 109.25  
Channel slope = 0.0141 ft/ft  
Channel side slope = not applicable  
Area of flow = 6 ft<sup>2</sup>  
Hydraulic radius = 0.857

## Section Description

## Water Surface Elevation

Normal depth = 0.62 ft  
Critical depth = 0.95 ft  
Depth downstream = 2.04 ft  
Bend loss = 0 ft  
Depth upstream = 1.96 ft  
Velocity = 2.57 ft/s  
Flow profile = Steep

### **AB 4 Influent Split Box-Channel**

**111.34**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 12 ft  
Channel width/diameter = 4.5 ft  
Flow = 10.179 mgd  
Downstream channel invert = 110  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 5.79 ft<sup>2</sup>  
Hydraulic radius = 0.819  
Normal depth = infinite  
Critical depth = 0.72 ft  
Depth downstream = 1.28 ft  
Bend loss = 0.05 ft  
Depth upstream = 1.34 ft  
Velocity = 2.73 ft/s  
Flow profile = Horizontal

### **AB 3/4 42-IN Influent Pipe**

**111.42**

Pipe shape = Circular  
Diameter = 42 in  
Length = 58 ft  
Flow = 10.179 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.5  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 1.64 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.06 ft  
Total loss = 0.08 ft

### **42-IN Tee to AB 3/4**

**111.44**

Tee type = run of tee  
Diameter of pipe run past tee = 42 in

**Section Description**

**Water Surface Elevation**

Flow through tee = 10.179 mgd  
Velocity through tee = 1.64 ft/s  
Total tee K value = 0.6  
Overall head loss = 0.02 ft

**42-IN PC Effluent to PC Junction Box**

**112.33**

Pipe shape = Circular  
Diameter = 42 in  
Length = 244 ft  
Flow = 20.34 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 2.348  
Solids factor = 1  
Velocity = 3.27 ft/s  
Friction loss = 0.72 ft  
Fitting loss = 0.17 ft  
Total loss = 0.88 ft

**Prim. Eff. Junction Box**

**112.33**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 16.5 ft  
Channel width/diameter = 7 ft  
Flow = 20.34 mgd  
Downstream channel invert = 104.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 54.81 ft<sup>2</sup>  
Hydraulic radius = 2.419  
Normal depth = infinite  
Critical depth = 0.86 ft  
Depth downstream = 7.83 ft  
Bend loss = 0 ft  
Depth upstream = 7.83 ft  
Velocity = 0.57 ft/s  
Flow profile = Horizontal

**PC 2 24-IN Effluent**

**112.48**

Pipe shape = Circular  
Diameter = 24 in  
Length = 15 ft  
Flow = 3.767 mgd  
Friction method = Hazen Williams

## Section Description

## Water Surface Elevation

Friction factor = 100  
Total fitting K value = 2.2  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 1.85 ft/s  
Friction loss = 0.03 ft  
Fitting loss = 0.12 ft  
Total loss = 0.15 ft

### **PC 2 Effluent Box**

**112.48**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 1.5 ft  
Channel width/diameter = 4 ft  
Flow = 3.767 mgd  
Downstream channel invert = 106  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 25.92 ft<sup>2</sup>  
Hydraulic radius = 1.528  
Normal depth = infinite  
Critical depth = 0.4 ft  
Depth downstream = 6.48 ft  
Bend loss = 0 ft  
Depth upstream = 6.48 ft  
Velocity = 0.22 ft/s  
Flow profile = Horizontal

### **PC 2 Effluent Launder**

**113.11**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 71 ft  
Channel width/diameter = 1 ft  
Flow = 1.883 mgd  
Downstream channel invert = 112  
Channel slope = 0.0015 ft/ft  
Channel side slope = not applicable  
Area of flow = 0.82 ft<sup>2</sup>  
Hydraulic radius = 0.311  
Normal depth = 1.22 ft  
Critical depth = 0.64 ft  
Depth downstream = 0.64 ft  
Bend loss = 0 ft  
Depth upstream = 1 ft  
Velocity = 4.54 ft/s

## Section Description

## Water Surface Elevation

Flow profile = Mild

### **PC 2 Effluent Weir**

**114.41**

Invert of V notch = 114.25

Angle of V notch = 90 degrees

Number of notches = 212

Total flow over weir = 3.767 mgd

Weir submergence = unsubmerged

Head over weir = 0.16 ft

### **PC 2 Basin**

**114.42**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 45 ft

Channel width/diameter = 45 ft

Flow = 3.767 mgd

Downstream channel invert = 106

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 378.68 ft<sup>2</sup>

Hydraulic radius = 6.125

Normal depth = infinite

Critical depth = 0.08 ft

Depth downstream = 8.41 ft

Bend loss = 0 ft

Depth upstream = 8.42 ft

Velocity = 0.02 ft/s

Flow profile = Horizontal

### **PC 2 Influent Well**

**114.68**

Pipe shape = Circular

Diameter = 18 in

Length = 7 ft

Flow = 3.767 mgd

Friction method = Hazen Williams

Friction factor = 100

Total fitting K value = 1.25

Pipe area = 1.77 ft<sup>2</sup>

Pipe hydraulic radius = 0.375

Age factor = 2.348

Solids factor = 1

Velocity = 3.3 ft/s

Friction loss = 0.06 ft

Fitting loss = 0.21 ft

Total loss = 0.27 ft

### **24-IN Influent Pipe**

**114.72**

Pipe shape = Circular

## Section Description

## Water Surface Elevation

Diameter = 24 in  
Length = 10 ft  
Flow = 3.767 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 0.42  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 1.85 ft/s  
Friction loss = 0.02 ft  
Fitting loss = 0.02 ft  
Total loss = 0.04 ft

### **36-IN PC Influent Pipe**

**114.83**

Pipe shape = Circular  
Diameter = 24 in  
Length = 10 ft  
Flow = 3.767 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1.67  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 1.85 ft/s  
Friction loss = 0.02 ft  
Fitting loss = 0.09 ft  
Total loss = 0.11 ft

### **Drop Box to Primary Clarifier No 2**

**114.83**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3.5 ft  
Channel width/diameter = 3.5 ft  
Flow = 3.767 mgd  
Downstream channel invert = 108  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 23.91 ft<sup>2</sup>  
Hydraulic radius = 1.393  
Normal depth = infinite  
Critical depth = 0.44 ft  
Depth downstream = 6.83 ft  
Bend loss = 0 ft

**Section Description**

**Water Surface Elevation**

Depth upstream = 6.83 ft

Velocity = 0.24 ft/s

Flow profile = Horizontal

**Primary Clarifier Distribution Box Weir**

**117.63**

Weir invert (top of weir) = 117

Weir length = 3.5 ft

Weir 'C' coefficient = 3.33

Flow over weir = 3.748 mgd

Weir submergence = unsubmerged

Head over weir = 0.63 ft

## Pinole MM-MD Flow.vhf

### Hydraulic Profile

#### Current flow conditions

| Forward Flow | Return I Flow | Return II Flow | Return III Flow |
|--------------|---------------|----------------|-----------------|
| 6.06 mgd     | 4.87 mgd      | 12.18 mgd      | -----           |

#### Section Description

#### Water Surface Elevation

**Starting water surface elevation**

**107**

#### **Effluent Weir**

**107.61**

Weir invert (top of weir) = 107.15

Weir length = 4.5 ft

Weir 'C' coefficient = 3.33

Flow over weir = 3.03 mgd

Weir submergence = unsubmerged

Head over weir = 0.46 ft

#### **Chlorine Contact Basin**

**107.62**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 140 ft

Channel width/diameter = 4 ft

Flow = 3.03 mgd

Downstream channel invert = 103.25

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 17.44 ft<sup>2</sup>

Hydraulic radius = 1.371

Normal depth = infinite

Critical depth = 0.35 ft

Depth downstream = 4.36 ft

Bend loss = 0.01 ft

Depth upstream = 4.37 ft

Velocity = 0.27 ft/s

Flow profile = Horizontal

#### **Slide Gate**

**107.65**

Opening type = rectangular gate

Opening diameter/width = 36 in

Gate height = 24 in

Invert = 103.25

Number of gates = 1

Flow through gate(s) = 3.03 mgd

## Section Description

## Water Surface Elevation

Total area of opening(s) = 6 ft<sup>2</sup>  
Velocity through gate(s) = 0.78 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.02 ft  
Downstream water level = 107.62  
Upstream water level = 107.65

### **CC Basin Influent Box**

**107.65**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 8 ft  
Channel width/diameter = 4 ft  
Flow = 6.06 mgd  
Downstream channel invert = 103.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 17.58 ft<sup>2</sup>  
Hydraulic radius = 1.375  
Normal depth = infinite  
Critical depth = 0.55 ft  
Depth downstream = 4.4 ft  
Bend loss = 0 ft  
Depth upstream = 4.4 ft  
Velocity = 0.53 ft/s  
Flow profile = Horizontal

### **42-IN SC Effluent**

**107.68**

Pipe shape = Circular  
Diameter = 42 in  
Length = 116 ft  
Flow = 6.06 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.75  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 0.97 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.03 ft  
Total loss = 0.04 ft

### **SC #2 Effluent Connection**

**107.69**

Tee type = branch to line  
Diameter of pipe line = 42 in  
Diameter of pipe branch = 30 in

**Section Description****Water Surface Elevation**

Flow through tee = 1.818 mgd  
Velocity through tee = 0.57 ft/s  
Total tee K value = 1.69  
Overall head loss = 0.01 ft

**SC #2 - 36-IN Effluent****107.69**

Pipe shape = Circular  
Diameter = 36 in  
Length = 70 ft  
Flow = 1.818 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 0.4 ft/s  
Friction loss = 0 ft  
Fitting loss = 0 ft  
Total loss = 0 ft

**SC #2 Effluent Box****107.69**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 4 ft  
Channel width/diameter = 4 ft  
Flow = 2.01 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 70.76 ft<sup>2</sup>  
Hydraulic radius = 1.797  
Normal depth = infinite  
Critical depth = 0.27 ft  
Depth downstream = 17.69 ft  
Bend loss = 0 ft  
Depth upstream = 17.69 ft  
Velocity = 0.04 ft/s  
Flow profile = Horizontal

**SC #2 Effluent Launder****107.87**

Launder invert = 107  
Launder length = 100 ft  
Launder width = 1 ft  
Launder slope = 0.004 ft/ft  
Flow through launder = 0.912 mgd

**Section Description****Water Surface Elevation**

Critical depth = 0.4 ft  
Downstream depth = 0.69 ft  
Upstream depth = 0.47 ft

**SC #2 Effluent Weir****109.38**

Invert of V notch = 109.3  
Angle of V notch = 90 degrees  
Number of notches = 594  
Total flow over weir = 2.01 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.08 ft

**SC #2****109.39**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 75 ft  
Channel width/diameter = 75 ft  
Flow = 3.278 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 1453.9 ft<sup>2</sup>  
Hydraulic radius = 12.779  
Normal depth = infinite  
Critical depth = 0.05 ft  
Depth downstream = 19.38 ft  
Bend loss = 0 ft  
Depth upstream = 19.39 ft  
Velocity = 0 ft/s  
Flow profile = Horizontal

**SC #2 Inlet Ports****109.41**

Opening type = rectangular orifice  
Opening diameter/width = 6 in  
Opening height = 30 in  
Invert = 106  
Number of openings = 6  
Flow through opening(s) = 3.332 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through opening(s) = 0.69 ft/s  
Flow behavior = orifice, downstream control  
Orifice loss = 0.02 ft  
Downstream water level = 109.39  
Upstream water level = 109.41

**SC #2 - 36-IN Influent****109.43**

Pipe shape = Circular  
Diameter = 36 in

## Section Description

## Water Surface Elevation

Length = 200 ft  
Flow = 3.278 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 2  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 0.72 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.02 ft  
Total loss = 0.03 ft

### **SC #2 Influent Box**

**109.43**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3 ft  
Channel width/diameter = 7 ft  
Flow = 3.278 mgd  
Downstream channel invert = 100  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 66.01 ft<sup>2</sup>  
Hydraulic radius = 2.553  
Normal depth = infinite  
Critical depth = 0.25 ft  
Depth downstream = 9.43 ft  
Bend loss = 0 ft  
Depth upstream = 9.43 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **SC Dist Box Weir #5**

**110.38**

Weir invert (top of weir) = 110  
Weir length = 7 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 3.47 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.38 ft

### **SC Distribution Box**

**110.38**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 9 ft  
Channel width/diameter = 35 ft  
Flow = 10.93 mgd

## Section Description

## Water Surface Elevation

Downstream channel invert = 105.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 170.66 ft<sup>2</sup>  
Hydraulic radius = 3.813  
Normal depth = infinite  
Critical depth = 0.19 ft  
Depth downstream = 4.88 ft  
Bend loss = 0 ft  
Depth upstream = 4.88 ft  
Velocity = 0.1 ft/s  
Flow profile = Horizontal

### **AB 36-IN Effluent**

**110.42**

Pipe shape = Circular  
Diameter = 36 in  
Length = 5 ft  
Flow = 5.465 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.76  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 1.2 ft/s  
Friction loss = 0 ft  
Fitting loss = 0.04 ft  
Total loss = 0.04 ft

### **Effluent Gate**

**110.48**

Opening type = circular gate  
Opening diameter/width = 36 in  
Gate height = 36 in  
Invert = 106  
Number of gates = 1  
Flow through gate(s) = 5.47 mgd  
Total area of opening(s) = 7.07 ft<sup>2</sup>  
Velocity through gate(s) = 1.2 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.06 ft  
Downstream water level = 110.42  
Upstream water level = 110.48

### **AB 3 ML Drop Box**

**110.48**

Channel shape = Rectangular  
Manning's 'n' = 0.012

## Section Description

## Water Surface Elevation

Channel length = 3 ft  
Channel width/diameter = 3 ft  
Flow = 5.47 mgd  
Downstream channel invert = 105.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 14.95 ft<sup>2</sup>  
Hydraulic radius = 1.153  
Normal depth = infinite  
Critical depth = 0.63 ft  
Depth downstream = 4.98 ft  
Bend loss = 0 ft  
Depth upstream = 4.98 ft  
Velocity = 0.57 ft/s  
Flow profile = Horizontal

### **AB 3 ML Effluent Channel**

**110.49**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 5.5 ft  
Channel width/diameter = 3 ft  
Flow = 5.47 mgd  
Downstream channel invert = 109.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 3.71 ft<sup>2</sup>  
Hydraulic radius = 0.678  
Normal depth = infinite  
Critical depth = 0.63 ft  
Depth downstream = 1.23 ft  
Bend loss = 0 ft  
Depth upstream = 1.24 ft  
Velocity = 2.29 ft/s  
Flow profile = Horizontal

### **AB 3 Effluent Sluice Gate**

**110.54**

Opening type = rectangular gate  
Opening diameter/width = 36 in  
Gate height = 30 in  
Invert = 109.25  
Number of gates = 1  
Flow through gate(s) = 5.47 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through gate(s) = 1.13 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.05 ft  
Downstream water level = 110.49

## Section Description

## Water Surface Elevation

Upstream water level = 110.54

### **AB 3 Zone E**

**110.54**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 11.56 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 280.81 ft<sup>2</sup>  
Hydraulic radius = 5.84  
Normal depth = infinite  
Critical depth = 0.29 ft  
Depth downstream = 14.04 ft  
Bend loss = 0 ft  
Depth upstream = 14.04 ft  
Velocity = 0.06 ft/s  
Flow profile = Horizontal

### **Baffle Wall E to D**

**110.56**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 11.56 mgd  
Weir submergence = fully submerged  
Head over weir = 1.56 ft

### **Contact Stabilization Influent Pipe**

**110.69**

Pipe shape = Circular  
Diameter = 24 in  
Length = 100 ft  
Flow = 6.06 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 0  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 1  
Solids factor = 1  
Velocity = 2.98 ft/s  
Friction loss = 0.14 ft  
Fitting loss = 0 ft  
Total loss = 0.14 ft

### **AB 3 Zone D**

**110.56**

## Section Description

## Water Surface Elevation

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 11.56 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 281.25 ft<sup>2</sup>  
Hydraulic radius = 5.844  
Normal depth = infinite  
Critical depth = 0.29 ft  
Depth downstream = 14.06 ft  
Bend loss = 0 ft  
Depth upstream = 14.06 ft  
Velocity = 0.06 ft/s  
Flow profile = Horizontal

### **Baffle Wall D to C**

**110.58**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 11.56 mgd  
Weir submergence = fully submerged  
Head over weir = 1.58 ft

### **AB 4 Zone C**

**110.59**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 130 ft  
Channel width/diameter = 20 ft  
Flow = 11.56 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 281.69 ft<sup>2</sup>  
Hydraulic radius = 5.848  
Normal depth = infinite  
Critical depth = 0.29 ft  
Depth downstream = 14.08 ft  
Bend loss = 0 ft  
Depth upstream = 14.09 ft  
Velocity = 0.06 ft/s  
Flow profile = Horizontal

### **Baffle Wall C to B**

**110.61**

Weir invert (top of weir) = 109

**Section Description****Water Surface Elevation**

Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 11.56 mgd  
Weir submergence = fully submerged  
Head over weir = 1.61 ft

**AB Zone B****110.61**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 30 ft  
Channel width/diameter = 20 ft  
Flow = 11.56 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 282.13 ft<sup>2</sup>  
Hydraulic radius = 5.852  
Normal depth = infinite  
Critical depth = 0.29 ft  
Depth downstream = 14.11 ft  
Bend loss = 0 ft  
Depth upstream = 14.11 ft  
Velocity = 0.06 ft/s  
Flow profile = Horizontal

**Baffle Wall B to A****110.63**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 11.56 mgd  
Weir submergence = fully submerged  
Head over weir = 1.63 ft

**AB Zone A****110.63**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 30 ft  
Channel width/diameter = 20 ft  
Flow = 11.56 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 282.57 ft<sup>2</sup>  
Hydraulic radius = 5.856  
Normal depth = infinite  
Critical depth = 0.29 ft  
Depth downstream = 14.13 ft  
Bend loss = 0 ft

## Section Description

## Water Surface Elevation

Depth upstream = 14.13 ft  
Velocity = 0.06 ft/s  
Flow profile = Horizontal

### **AB 4 Influent Sluice Gate**

**110.64**

Opening type = rectangular gate  
Opening diameter/width = 36 in  
Gate height = 30 in  
Invert = 110  
Number of gates = 2  
Flow through gate(s) = 5.47 mgd  
Total area of opening(s) = 15 ft<sup>2</sup>  
Velocity through gate(s) = 0.56 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.01 ft  
Downstream water level = 110.63  
Upstream water level = 110.64

### **AB 4 Influent Channel**

**110.65**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 4 ft  
Channel width/diameter = 3 ft  
Flow = 5.47 mgd  
Downstream channel invert = 109.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 4.18 ft<sup>2</sup>  
Hydraulic radius = 0.723  
Normal depth = infinite  
Critical depth = 0.63 ft  
Depth downstream = 1.39 ft  
Bend loss = 0 ft  
Depth upstream = 1.4 ft  
Velocity = 2.02 ft/s  
Flow profile = Horizontal

### **AB 4 Influent Sloped Channel**

**110.64**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 5.3 ft  
Channel width/diameter = 3 ft  
Flow = 5.47 mgd  
Downstream channel invert = 109.25  
Channel slope = 0.0141 ft/ft  
Channel side slope = not applicable  
Area of flow = 4.07 ft<sup>2</sup>  
Hydraulic radius = 0.712

## Section Description

## Water Surface Elevation

Normal depth = 0.41 ft  
Critical depth = 0.63 ft  
Depth downstream = 1.4 ft  
Bend loss = 0 ft  
Depth upstream = 1.31 ft  
Velocity = 2.02 ft/s  
Flow profile = Steep

### **AB 4 Influent Split Box-Channel**

**110.72**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 12 ft  
Channel width/diameter = 4.5 ft  
Flow = 5.47 mgd  
Downstream channel invert = 110  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 2.94 ft<sup>2</sup>  
Hydraulic radius = 0.506  
Normal depth = infinite  
Critical depth = 0.48 ft  
Depth downstream = 0.64 ft  
Bend loss = 0.05 ft  
Depth upstream = 0.72 ft  
Velocity = 2.94 ft/s  
Flow profile = Horizontal

### **AB 3/4 42-IN Influent Pipe**

**110.74**

Pipe shape = Circular  
Diameter = 42 in  
Length = 58 ft  
Flow = 5.47 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.5  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 0.88 ft/s  
Friction loss = 0 ft  
Fitting loss = 0.02 ft  
Total loss = 0.02 ft

### **42-IN Tee to AB 3/4**

**110.75**

Tee type = run of tee  
Diameter of pipe run past tee = 42 in

**Section Description****Water Surface Elevation**

Flow through tee = 5.47 mgd  
Velocity through tee = 0.88 ft/s  
Total tee K value = 0.6  
Overall head loss = 0.01 ft

**42-IN PC Effluent to PC Junction Box****111.02**

Pipe shape = Circular  
Diameter = 42 in  
Length = 244 ft  
Flow = 10.93 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 2.348  
Solids factor = 1  
Velocity = 1.76 ft/s  
Friction loss = 0.23 ft  
Fitting loss = 0.05 ft  
Total loss = 0.28 ft

**Prim. Eff. Junction Box****111.02**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 16.5 ft  
Channel width/diameter = 7 ft  
Flow = 10.93 mgd  
Downstream channel invert = 104.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 45.64 ft<sup>2</sup>  
Hydraulic radius = 2.278  
Normal depth = infinite  
Critical depth = 0.57 ft  
Depth downstream = 6.52 ft  
Bend loss = 0 ft  
Depth upstream = 6.52 ft  
Velocity = 0.37 ft/s  
Flow profile = Horizontal

**PC 2 24-IN Effluent****111.07**

Pipe shape = Circular  
Diameter = 24 in  
Length = 15 ft  
Flow = 2.02 mgd  
Friction method = Hazen Williams

## Section Description

## Water Surface Elevation

Friction factor = 100  
Total fitting K value = 2.2  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 0.99 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.03 ft  
Total loss = 0.04 ft

### **PC 2 Effluent Box**

**111.07**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 1.5 ft  
Channel width/diameter = 4 ft  
Flow = 2.02 mgd  
Downstream channel invert = 106  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 20.28 ft<sup>2</sup>  
Hydraulic radius = 1.434  
Normal depth = infinite  
Critical depth = 0.27 ft  
Depth downstream = 5.07 ft  
Bend loss = 0 ft  
Depth upstream = 5.07 ft  
Velocity = 0.15 ft/s  
Flow profile = Horizontal

### **PC 2 Effluent Launder**

**112.78**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 71 ft  
Channel width/diameter = 1 ft  
Flow = 1.01 mgd  
Downstream channel invert = 112  
Channel slope = 0.0015 ft/ft  
Channel side slope = not applicable  
Area of flow = 0.55 ft<sup>2</sup>  
Hydraulic radius = 0.261  
Normal depth = 0.74 ft  
Critical depth = 0.42 ft  
Depth downstream = 0.42 ft  
Bend loss = 0 ft  
Depth upstream = 0.67 ft  
Velocity = 3.69 ft/s

**Section Description****Water Surface Elevation**

Flow profile = Mild

**PC 2 Effluent Weir****114.38**

Invert of V notch = 114.25

Angle of V notch = 90 degrees

Number of notches = 212

Total flow over weir = 2.02 mgd

Weir submergence = unsubmerged

Head over weir = 0.13 ft

**PC 2 Basin****114.38**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 45 ft

Channel width/diameter = 45 ft

Flow = 2.02 mgd

Downstream channel invert = 106

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 377.05 ft<sup>2</sup>

Hydraulic radius = 6.105

Normal depth = infinite

Critical depth = 0.05 ft

Depth downstream = 8.38 ft

Bend loss = 0 ft

Depth upstream = 8.38 ft

Velocity = 0.01 ft/s

Flow profile = Horizontal

**PC 2 Influent Well****114.46**

Pipe shape = Circular

Diameter = 18 in

Length = 7 ft

Flow = 2.02 mgd

Friction method = Hazen Williams

Friction factor = 100

Total fitting K value = 1.25

Pipe area = 1.77 ft<sup>2</sup>

Pipe hydraulic radius = 0.375

Age factor = 2.348

Solids factor = 1

Velocity = 1.77 ft/s

Friction loss = 0.02 ft

Fitting loss = 0.06 ft

Total loss = 0.08 ft

**24-IN Influent Pipe****114.47**

Pipe shape = Circular

## Section Description

## Water Surface Elevation

Diameter = 24 in  
Length = 10 ft  
Flow = 2.02 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 0.42  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 0.99 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.01 ft  
Total loss = 0.01 ft

### **36-IN PC Influent Pipe**

**114.5**

Pipe shape = Circular  
Diameter = 24 in  
Length = 10 ft  
Flow = 2.02 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1.67  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 0.99 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.03 ft  
Total loss = 0.03 ft

### **Drop Box to Primary Clarifier No 2**

**114.5**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3.5 ft  
Channel width/diameter = 3.5 ft  
Flow = 2.02 mgd  
Downstream channel invert = 108  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 22.75 ft<sup>2</sup>  
Hydraulic radius = 1.379  
Normal depth = infinite  
Critical depth = 0.29 ft  
Depth downstream = 6.5 ft  
Bend loss = 0 ft

**Section Description**

**Water Surface Elevation**

Depth upstream = 6.5 ft  
Velocity = 0.14 ft/s  
Flow profile = Horizontal

**Primary Clarifier Distribution Box Weir**

**117.41**

Weir invert (top of weir) = 117  
Weir length = 3.5 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 2.01 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.41 ft

# Pinole PWWF Flow.vhf

## Hydraulic Profile

### Current flow conditions

| Forward Flow | Return I Flow | Return II Flow | Return III Flow |
|--------------|---------------|----------------|-----------------|
| 20 mgd       | 10 mgd        | -----          | -----           |

### Section Description

### Water Surface Elevation

**Starting water surface elevation**

**107**

#### **Effluent Weir**

**108.17**

Weir invert (top of weir) = 107.15

Weir length = 4.5 ft

Weir 'C' coefficient = 3.33

Flow over weir = 10 mgd

Weir submergence = unsubmerged

Head over weir = 1.02 ft

#### **Chlorine Contact Basin**

**108.18**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 140 ft

Channel width/diameter = 4 ft

Flow = 10 mgd

Downstream channel invert = 103.25

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 19.69 ft<sup>2</sup>

Hydraulic radius = 1.422

Normal depth = infinite

Critical depth = 0.77 ft

Depth downstream = 4.92 ft

Bend loss = 0 ft

Depth upstream = 4.93 ft

Velocity = 0.79 ft/s

Flow profile = Horizontal

#### **Slide Gate**

**108.45**

Opening type = rectangular gate

Opening diameter/width = 36 in

Gate height = 24 in

Invert = 103.25

Number of gates = 1

Flow through gate(s) = 10 mgd

## Section Description

## Water Surface Elevation

Total area of opening(s) = 6 ft<sup>2</sup>  
Velocity through gate(s) = 2.58 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.27 ft  
Downstream water level = 108.18  
Upstream water level = 108.45

### **CC Basin Influent Box**

**108.45**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 8 ft  
Channel width/diameter = 4 ft  
Flow = 20 mgd  
Downstream channel invert = 103.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 20.8 ft<sup>2</sup>  
Hydraulic radius = 1.444  
Normal depth = infinite  
Critical depth = 1.23 ft  
Depth downstream = 5.2 ft  
Bend loss = 0 ft  
Depth upstream = 5.2 ft  
Velocity = 1.49 ft/s  
Flow profile = Horizontal

### **42-IN SC Effluent**

**108.83**

Pipe shape = Circular  
Diameter = 42 in  
Length = 116 ft  
Flow = 20 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.75  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 3.22 ft/s  
Friction loss = 0.1 ft  
Fitting loss = 0.28 ft  
Total loss = 0.38 ft

### **SC #1 Effluent Connection**

**108.85**

Tee type = branch to line  
Diameter of pipe line = 42 in  
Diameter of pipe branch = 42 in

**Section Description****Water Surface Elevation**

Flow through tee = 6 mgd  
Velocity through tee = 0.96 ft/s  
Total tee K value = 1.5  
Overall head loss = 0.02 ft

**SC #1 - 30-IN Effluent****108.87**

Pipe shape = Circular  
Diameter = 42 in  
Length = 70 ft  
Flow = 6 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 1  
Solids factor = 1  
Velocity = 0.96 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.01 ft  
Total loss = 0.02 ft

**SC #1 Effluent Box****108.87**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 4 ft  
Channel width/diameter = 4 ft  
Flow = 6 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 75.48 ft<sup>2</sup>  
Hydraulic radius = 1.808  
Normal depth = infinite  
Critical depth = 0.55 ft  
Depth downstream = 18.87 ft  
Bend loss = 0 ft  
Depth upstream = 18.87 ft  
Velocity = 0.12 ft/s  
Flow profile = Horizontal

**SC #1 Effluent Launder****109.26**

Launder invert = 107  
Launder length = 100 ft  
Launder width = 1 ft  
Launder slope = 0.004 ft/ft  
Flow through launder = 3 mgd

**Section Description****Water Surface Elevation**

Critical depth = 0.87 ft  
Downstream depth = 1.87 ft  
Upstream depth = 1.86 ft

**SC #1 Effluent Weir** **109.43**

Invert of V notch = 109.3  
Angle of V notch = 90 degrees  
Number of notches = 594  
Total flow over weir = 6 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.13 ft

**SC #1** **109.43**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 75 ft  
Channel width/diameter = 75 ft  
Flow = 9 mgd  
Downstream channel invert = 90  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 1457.39 ft<sup>2</sup>  
Hydraulic radius = 12.799  
Normal depth = infinite  
Critical depth = 0.1 ft  
Depth downstream = 19.43 ft  
Bend loss = 0 ft  
Depth upstream = 19.43 ft  
Velocity = 0.01 ft/s  
Flow profile = Horizontal

**SC #2 Influent Ports** **109.57**

Opening type = rectangular orifice  
Opening diameter/width = 6 in  
Opening height = 30 in  
Invert = 106  
Number of openings = 6  
Flow through opening(s) = 9 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through opening(s) = 1.86 ft/s  
Flow behavior = orifice, downstream control  
Orifice loss = 0.14 ft  
Downstream water level = 109.43  
Upstream water level = 109.57

**SC #2 - 36-IN Influent** **109.78**

Pipe shape = Circular  
Diameter = 36 in

## Section Description

## Water Surface Elevation

Length = 200 ft  
Flow = 9 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 2  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 1.97 ft/s  
Friction loss = 0.08 ft  
Fitting loss = 0.12 ft  
Total loss = 0.2 ft

### **SC #1 Drop box**

**109.78**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 3 ft  
Channel width/diameter = 8 ft  
Flow = 9 mgd  
Downstream channel invert = 100  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 78.24 ft<sup>2</sup>  
Hydraulic radius = 2.839  
Normal depth = infinite  
Critical depth = 0.46 ft  
Depth downstream = 9.78 ft  
Bend loss = 0 ft  
Depth upstream = 9.78 ft  
Velocity = 0.18 ft/s  
Flow profile = Horizontal

### **SC Dist Box Weir #5**

**110.71**

Weir invert (top of weir) = 110  
Weir length = 7 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 9 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.71 ft

### **SC Distribution Box**

**110.71**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 9 ft  
Channel width/diameter = 30 ft  
Flow = 30 mgd

## Section Description

## Water Surface Elevation

Downstream channel invert = 100  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 321.29 ft<sup>2</sup>  
Hydraulic radius = 6.248  
Normal depth = infinite  
Critical depth = 0.42 ft  
Depth downstream = 10.71 ft  
Bend loss = 0 ft  
Depth upstream = 10.71 ft  
Velocity = 0.14 ft/s  
Flow profile = Horizontal

### **AB 36-IN Effluent**

**111.01**

Pipe shape = Circular  
Diameter = 36 in  
Length = 5 ft  
Flow = 15 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.76  
Pipe area = 7.07 ft<sup>2</sup>  
Pipe hydraulic radius = 0.75  
Age factor = 1  
Solids factor = 1  
Velocity = 3.28 ft/s  
Friction loss = 0.01 ft  
Fitting loss = 0.29 ft  
Total loss = 0.3 ft

### **AB Exit Gate**

**111.48**

Opening type = circular gate  
Opening diameter/width = 36 in  
Gate height = 36 in  
Invert = 106  
Number of gates = 1  
Flow through gate(s) = 15.01 mgd  
Total area of opening(s) = 7.07 ft<sup>2</sup>  
Velocity through gate(s) = 3.29 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.47 ft  
Downstream water level = 111.01  
Upstream water level = 111.48

### **AB 3 ML Drop Box**

**111.48**

Channel shape = Rectangular  
Manning's 'n' = 0.012

## Section Description

## Water Surface Elevation

Channel length = 3 ft  
Channel width/diameter = 3 ft  
Flow = 15.01 mgd  
Downstream channel invert = 105.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 17.93 ft<sup>2</sup>  
Hydraulic radius = 1.199  
Normal depth = infinite  
Critical depth = 1.23 ft  
Depth downstream = 5.98 ft  
Bend loss = 0 ft  
Depth upstream = 5.98 ft  
Velocity = 1.3 ft/s  
Flow profile = Horizontal

### **AB 3 ML Effluent Channel**

**111.49**

Channel shape = Rectangular  
Manning's 'n' = 0.013  
Channel length = 5.5 ft  
Channel width/diameter = 3 ft  
Flow = 15.01 mgd  
Downstream channel invert = 109.25  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 6.69 ft<sup>2</sup>  
Hydraulic radius = 0.897  
Normal depth = infinite  
Critical depth = 1.23 ft  
Depth downstream = 2.23 ft  
Bend loss = 0 ft  
Depth upstream = 2.24 ft  
Velocity = 3.47 ft/s  
Flow profile = Horizontal

### **AB 3 Effluent Sluice Gate**

**111.87**

Opening type = rectangular gate  
Opening diameter/width = 36 in  
Gate height = 30 in  
Invert = 109.25  
Number of gates = 1  
Flow through gate(s) = 15.01 mgd  
Total area of opening(s) = 7.5 ft<sup>2</sup>  
Velocity through gate(s) = 3.1 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.39 ft  
Downstream water level = 111.49

## Section Description

## Water Surface Elevation

Upstream water level = 111.87

### **AB 3 Zone E**

**111.87**

Channel shape = Rectangular  
Manning's 'n' = 0.013  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 15.01 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 307.46 ft<sup>2</sup>  
Hydraulic radius = 6.059  
Normal depth = infinite  
Critical depth = 0.35 ft  
Depth downstream = 15.37 ft  
Bend loss = 0 ft  
Depth upstream = 15.37 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

### **Baffle Wall E to D**

**111.89**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 15 mgd  
Weir submergence = fully submerged  
Head over weir = 2.89 ft

### **Step Feed Gates AB No 3**

**111.9**

Opening type = rectangular gate  
Opening diameter/width = 24 in  
Gate height = 36 in  
Invert = 110.5  
Number of gates = 3  
Flow through gate(s) = 10 mgd  
Total area of opening(s) = 18 ft<sup>2</sup>  
Velocity through gate(s) = 0.86 ft/s  
Flow behavior = orifice, downstream control  
Gate loss = 0.03 ft  
Downstream water level = 111.87  
Upstream water level = 111.9

### **Step Feed Channel AB No 3**

**112.03**

Channel shape = Rectangular  
Manning's 'n' = 0.013  
Channel length = 108 ft

## Section Description

## Water Surface Elevation

Channel width/diameter = 3 ft  
Flow = 10 mgd  
Downstream channel invert = 110  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 5.84 ft<sup>2</sup>  
Hydraulic radius = 0.847  
Normal depth = infinite  
Critical depth = 0.94 ft  
Depth downstream = 1.9 ft  
Bend loss = 0.05 ft  
Depth upstream = 2.03 ft  
Velocity = 2.71 ft/s  
Flow profile = Horizontal

### **Step Feed Channel Bend**

**112.08**

Channel shape = Rectangular  
Manning's 'n' = 0.013  
Channel length = 8 ft  
Channel width/diameter = 3 ft  
Flow = 10 mgd  
Downstream channel invert = 110  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 6.11 ft<sup>2</sup>  
Hydraulic radius = 0.864  
Normal depth = infinite  
Critical depth = 0.94 ft  
Depth downstream = 2.03 ft  
Bend loss = 0.04 ft  
Depth upstream = 2.08 ft  
Velocity = 2.54 ft/s  
Flow profile = Horizontal

### **AB 3/4 Influent Pipe**

**112.19**

Pipe shape = Circular  
Diameter = 42 in  
Length = 54 ft  
Flow = 10 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1.7  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 2.348  
Solids factor = 1  
Velocity = 1.61 ft/s

**Section Description****Water Surface Elevation**

Friction loss = 0.04 ft  
Fitting loss = 0.07 ft  
Total loss = 0.11 ft

**42-IN Tee to AB 3/4****112.29**

Tee type = run of tee  
Diameter of pipe run past tee = 42 in  
Flow through tee = 20 mgd  
Velocity through tee = 3.22 ft/s  
Total tee K value = 0.6  
Overall head loss = 0.1 ft

**42-IN PC Effluent to PC Junction Box CS Mode****113.14**

Pipe shape = Circular  
Diameter = 42 in  
Length = 244 ft  
Flow = 20 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1  
Pipe area = 9.62 ft<sup>2</sup>  
Pipe hydraulic radius = 0.875  
Age factor = 2.348  
Solids factor = 1  
Velocity = 3.22 ft/s  
Friction loss = 0.7 ft  
Fitting loss = 0.16 ft  
Total loss = 0.86 ft

**Prim. Eff. Junction Box (CS Mode)****113.14**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 15.5 ft  
Channel width/diameter = 7 ft  
Flow = 20 mgd  
Downstream channel invert = 104.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 60.48 ft<sup>2</sup>  
Hydraulic radius = 2.491  
Normal depth = infinite  
Critical depth = 0.85 ft  
Depth downstream = 8.64 ft  
Bend loss = 0 ft  
Depth upstream = 8.64 ft  
Velocity = 0.51 ft/s  
Flow profile = Horizontal

**Section Description**

**Water Surface Elevation**

**PC 2 24-IN Effluent CS Mode**

**113.28**

Pipe shape = Circular  
Diameter = 24 in  
Length = 15 ft  
Flow = 4 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1.7  
Pipe area = 3.14 ft<sup>2</sup>  
Pipe hydraulic radius = 0.5  
Age factor = 2.348  
Solids factor = 1  
Velocity = 1.97 ft/s  
Friction loss = 0.03 ft  
Fitting loss = 0.1 ft  
Total loss = 0.14 ft

**PC 2 Effluent Box CS Mode**

**113.28**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 1.5 ft  
Channel width/diameter = 4 ft  
Flow = 4 mgd  
Downstream channel invert = 104.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 35.12 ft<sup>2</sup>  
Hydraulic radius = 1.629  
Normal depth = infinite  
Critical depth = 0.42 ft  
Depth downstream = 8.78 ft  
Bend loss = 0 ft  
Depth upstream = 8.78 ft  
Velocity = 0.18 ft/s  
Flow profile = Horizontal

**PC 2 Effluent Launder CS Mode**

**113.39**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 71 ft  
Channel width/diameter = 1 ft  
Flow = 2 mgd  
Downstream channel invert = 112  
Channel slope = 0.0015 ft/ft  
Channel side slope = not applicable  
Area of flow = 1.28 ft<sup>2</sup>  
Hydraulic radius = 0.36

## Section Description

## Water Surface Elevation

Normal depth = 1.28 ft  
Critical depth = 0.67 ft  
Depth downstream = 1.28 ft  
Bend loss = 0 ft  
Depth upstream = 1.28 ft  
Velocity = 2.41 ft/s  
Flow profile = Mild

### **PC 2 Effluent Weir CS Mode**

**114.42**

Invert of V notch = 114.25  
Angle of V notch = 90 degrees  
Number of notches = 212  
Total flow over weir = 4 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.17 ft

### **PC 2**

**114.42**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 45 ft  
Channel width/diameter = 45 ft  
Flow = 3.96 mgd  
Downstream channel invert = 106  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 378.86 ft<sup>2</sup>  
Hydraulic radius = 6.127  
Normal depth = infinite  
Critical depth = 0.08 ft  
Depth downstream = 8.42 ft  
Bend loss = 0 ft  
Depth upstream = 8.42 ft  
Velocity = 0.02 ft/s  
Flow profile = Horizontal

### **PC Influent Well**

**114.72**

Pipe shape = Circular  
Diameter = 18 in  
Length = 7 ft  
Flow = 4 mgd  
Friction method = Hazen Williams  
Friction factor = 100  
Total fitting K value = 1.25  
Pipe area = 1.77 ft<sup>2</sup>  
Pipe hydraulic radius = 0.375  
Age factor = 2.348  
Solids factor = 1  
Velocity = 3.5 ft/s

## Section Description

## Water Surface Elevation

Friction loss = 0.06 ft

Fitting loss = 0.24 ft

Total loss = 0.3 ft

### **24-IN PC Influent**

**114.79**

Pipe shape = Circular

Diameter = 24 in

Length = 15 ft

Flow = 4 mgd

Friction method = Hazen Williams

Friction factor = 100

Total fitting K value = 0.67

Pipe area = 3.14 ft<sup>2</sup>

Pipe hydraulic radius = 0.5

Age factor = 2.348

Solids factor = 1

Velocity = 1.97 ft/s

Friction loss = 0.03 ft

Fitting loss = 0.04 ft

Total loss = 0.07 ft

### **36-IN PC Influent**

**114.87**

Pipe shape = Circular

Diameter = 24 in

Length = 15 ft

Flow = 4 mgd

Friction method = Hazen Williams

Friction factor = 100

Total fitting K value = 0.75

Pipe area = 3.14 ft<sup>2</sup>

Pipe hydraulic radius = 0.5

Age factor = 2.348

Solids factor = 1

Velocity = 1.97 ft/s

Friction loss = 0.03 ft

Fitting loss = 0.05 ft

Total loss = 0.08 ft

### **Drop Box to PC 2**

**114.87**

Channel shape = Rectangular

Manning's 'n' = 0.012

Channel length = 3.5 ft

Channel width/diameter = 3.5 ft

Flow = 4 mgd

Downstream channel invert = 108

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 24.05 ft<sup>2</sup>

**Section Description****Water Surface Elevation**

Hydraulic radius = 1.395  
Normal depth = infinite  
Critical depth = 0.46 ft  
Depth downstream = 6.87 ft  
Bend loss = 0 ft  
Depth upstream = 6.87 ft  
Velocity = 0.26 ft/s  
Flow profile = Horizontal

**PC Distribution Box Weir to PC 2****117.66**

Weir invert (top of weir) = 117  
Weir length = 3.5 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 4 mgd  
Weir submergence = unsubmerged  
Head over weir = 0.66 ft

**AB 3 Zone D****111.9**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 95 ft  
Channel width/diameter = 20 ft  
Flow = 15.01 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 307.9 ft<sup>2</sup>  
Hydraulic radius = 6.062  
Normal depth = infinite  
Critical depth = 0.35 ft  
Depth downstream = 15.39 ft  
Bend loss = 0 ft  
Depth upstream = 15.4 ft  
Velocity = 0.08 ft/s  
Flow profile = Horizontal

**Baffle Wall D to C****111.92**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 5 mgd  
Weir submergence = fully submerged  
Head over weir = 2.92 ft

**AB 3 Zone C****111.92**

Channel shape = Rectangular  
Manning's 'n' = 0.013  
Channel length = 130 ft

## Section Description

## Water Surface Elevation

Channel width/diameter = 20 ft  
Flow = 5.01 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 308.34 ft<sup>2</sup>  
Hydraulic radius = 6.066  
Normal depth = infinite  
Critical depth = 0.17 ft  
Depth downstream = 15.42 ft  
Bend loss = 0 ft  
Depth upstream = 15.42 ft  
Velocity = 0.03 ft/s  
Flow profile = Horizontal

### **Baffle Wall C to B**

**111.94**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 5 mgd  
Weir submergence = fully submerged  
Head over weir = 2.94 ft

### **AB Zone B**

**111.94**

Channel shape = Rectangular  
Manning's 'n' = 0.013  
Channel length = 30 ft  
Channel width/diameter = 20 ft  
Flow = 5.01 mgd  
Downstream channel invert = 96.5  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 308.78 ft<sup>2</sup>  
Hydraulic radius = 6.069  
Normal depth = infinite  
Critical depth = 0.17 ft  
Depth downstream = 15.44 ft  
Bend loss = 0 ft  
Depth upstream = 15.44 ft  
Velocity = 0.03 ft/s  
Flow profile = Horizontal

### **Baffle Wall A to B**

**111.96**

Weir invert (top of weir) = 109  
Weir length = 20 ft  
Weir 'C' coefficient = 3.33  
Flow over weir = 5 mgd

## Section Description

## Water Surface Elevation

Weir submergence = fully submerged

Head over weir = 2.96 ft

### **AB Zone A**

**111.96**

Channel shape = Rectangular

Manning's 'n' = 0.013

Channel length = 30 ft

Channel width/diameter = 20 ft

Flow = 5.01 mgd

Downstream channel invert = 96.5

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 309.22 ft<sup>2</sup>

Hydraulic radius = 6.072

Normal depth = infinite

Critical depth = 0.17 ft

Depth downstream = 15.46 ft

Bend loss = 0 ft

Depth upstream = 15.46 ft

Velocity = 0.03 ft/s

Flow profile = Horizontal

### **AB 4 Influent Sluice Gate**

**111.97**

Opening type = rectangular gate

Opening diameter/width = 36 in

Gate height = 30 in

Invert = 110

Number of gates = 2

Flow through gate(s) = 5.01 mgd

Total area of opening(s) = 15 ft<sup>2</sup>

Velocity through gate(s) = 0.52 ft/s

Flow behavior = orifice, downstream control

Gate loss = 0.01 ft

Downstream water level = 111.96

Upstream water level = 111.97

### **AB 4 Influent Channel**

**111.98**

Channel shape = Rectangular

Manning's 'n' = 0.013

Channel length = 3 ft

Channel width/diameter = 3 ft

Flow = 5.01 mgd

Downstream channel invert = 109.25

Channel slope = 0 ft/ft

Channel side slope = not applicable

Area of flow = 8.17 ft<sup>2</sup>

Hydraulic radius = 0.967

Normal depth = infinite

## Section Description

## Water Surface Elevation

Critical depth = 0.59 ft  
Depth downstream = 2.72 ft  
Bend loss = 0 ft  
Depth upstream = 2.73 ft  
Velocity = 0.95 ft/s  
Flow profile = Horizontal

### **AB 4 Influent Slopped Channel**

**111.97**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 5.3 ft  
Channel width/diameter = 3 ft  
Flow = 15.01 mgd  
Downstream channel invert = 109.25  
Channel slope = 0.0141 ft/ft  
Channel side slope = not applicable  
Area of flow = 8.06 ft<sup>2</sup>  
Hydraulic radius = 0.962  
Normal depth = 0.81 ft  
Critical depth = 1.23 ft  
Depth downstream = 2.73 ft  
Bend loss = 0 ft  
Depth upstream = 2.64 ft  
Velocity = 2.84 ft/s  
Flow profile = Steep

### **AB 4 Influent Split Box-Channel**

**112.02**

Channel shape = Rectangular  
Manning's 'n' = 0.012  
Channel length = 12 ft  
Channel width/diameter = 4.5 ft  
Flow = 15.01 mgd  
Downstream channel invert = 110  
Channel slope = 0 ft/ft  
Channel side slope = not applicable  
Area of flow = 8.87 ft<sup>2</sup>  
Hydraulic radius = 1.051  
Normal depth = infinite  
Critical depth = 0.94 ft  
Depth downstream = 1.97 ft  
Bend loss = 0.04 ft  
Depth upstream = 2.02 ft  
Velocity = 2.62 ft/s  
Flow profile = Horizontal

### **10-IN RAS Influent Pipe**

**122.12**

Pipe shape = Circular

## **Section Description**

Diameter = 10 in  
Length = 58 ft  
Flow = 5 mgd  
Friction method = Hazen Williams  
Friction factor = 120  
Total fitting K value = 1.9  
Pipe area = 0.55 ft<sup>2</sup>  
Pipe hydraulic radius = 0.208  
Age factor = 1  
Solids factor = 1  
Velocity = 14.18 ft/s  
Friction loss = 4.17 ft  
Fitting loss = 5.93 ft  
Total loss = 10.1 ft

## **Water Surface Elevation**